



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2023/ 326

Dated: 03/11 /2023

FIRE SAFETY CERTIFICATE

Certified that M/s Bengali Sweets Centre located at G-19, South Extension Market, Part-I, New Delhi-110049, comprised of Basement, Ground plus three upper floors but the restaurant running at ground & first floor only have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 31/10/2023 in the presence of Mr. Ravinder Kumar Jain and that the Eating House (Ground & 1st Floor only) is fit for occupancy Class "Group D Assembly (Restaurant) as above with effect from 03/11 /2023 for a period of Three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 03/11/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

g/c

Copy to: -

1. The Dy. Health Officer (MCD) Public Health Officer (Green Park Zone) Aurobindo Marg, Green Park, New Delhi-110016 (w.r.t. MHA ID No. 2023101917496 dated 21/10/2023)
2. Mr. Ravinder Kumar Jain, M/s Bengali Sweets Centre at G-19, South Extension Market, Part-I, New Delhi-110049

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used strictly in accordance with Building Bye-Laws.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

18/N

INSPECTION REPORT

1	Name & Address of the Building	M/s Bengali Sweets Centre at G-19, South Extension Market, Part-I, New Delhi-49		
2	Type of Occupancy	Assembly "Group-D" (Restaurant)		
3	Building Comprised of	Basement, Ground + 3 upper floors but Restaurant at ground & 1 st floor only. 2 nd & 3 rd Floor (storage) locked.		
4	Type of Case	New case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No			
7	Date of Inspection	31/10/2023		
8	Name of the Inspecting Officers	ADO (SJ) Santosh Kumar		
9	Name & Designation of Officers from the building side	Mr. Ravinder Kumar Jain		
10	Year of construction	1965		
11	Applicant letter No. / MHA Portal	ID No. 2023101917496 dated 21.10.2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	2005 Circular Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6m	Provided	MR
	• Gate width	4.5m	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Two Exit	GF to 1 st Floor: 2 Nos GF to Terrace: 1 No	MR
	➤ Basement floor.	NA	NA	NA
	b) Width of Staircase			
	➤ Upper floors	Required	2 of 1m each & 1 of 1.5m to 1m	MR
	➤ Basement floor	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	NA	01 No	NA
	e) Width of corridor	NA	NA	NA
	f) Door size	Two Exit	1.5m & 1.5m	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers.			
	• Total numbers	06 Nos	06 Nos	MR
	• Types	ABC / CO ₂	Provided	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Required	01 No	MR
	• Length of hose-reel hose.	Required	30m	MR
	• Nozzle Diameter	Required	5mm	MR

N

ME

7	Automatic fire detection & alarming system.			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	Provided	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	Provided	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants.			
	• Size of Riser/Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	Required	1 No	MR
	• Hose box.	Required	1 No	MR
12	Yard Hydrants.			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting/Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	40m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	NA	NA	NA
	➤ Draw-off connection.	NA	NA	NA
	➤ Fire Service Inlet.	NA	NA	NA
	➤ Access to tank.	NA	NA	NA
	• Overhead tank capacity.	Required	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

2012

19	Fire Control Room.			
	• Detector system panel.	NA	NA	NA
	• Flow switch panel.	NA	NA	NA
	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
20	Special Fire Protection System for the Protection of Special Risk, if any.	NA	NA	NA

Note: The year of construction of building is shown as 1962 in the online application i.e. prior to the enactment of DFS Act and Rules. The applicant has also submitted copies of documents pertaining to his trade running in that premises i.e. Sales Tax Registration receipt of 1965, MCD License of 1984, Delhi Police License of 2006. Therefore, the requirements generated are as per circular 2005, if agreed please.

The Fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, issue of Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Signature]
 01/11/23
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

DO (SD)
[Signature]
 01/11/23
 C/o *[Signature]*
 2/11/2023
 Director *[Signature]*
 2/11/23
 ADO (SJ)

[Signature]
 2/11/23

As approved fair typed letter is put up for signature for.

[Signature]
 03/11/23
 Director *[Signature]*
 3/11/23

Uploaded