



C-12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/2023/EH/ 324

Dated 31 / 10 / 2023

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Gola Sizzlers (A Unit of Ark Foods) located at First Floor, Property No-21/31, Block-L, Mall Road, Civil Line, Delhi-110054 in a building comprised of basement, ground and 03 upper floors owned/ occupied by M/s Gola Sizzlers (A Unit of Ark Foods) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 26.10.2023 in the presence of Sh. Ankush Kapoor and that the building/ premise is fit for occupancy Class "Group D Assembly (Restaurant) at first floor only" with effect from 31/10/2023 for a period of Valid Up to 31.03.2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/10/2023 at New Delhi by

(Atul Garg)  
Director  
Ph-011-23414000

Copy to:-

1. M/s Gola Sizzlers (A Unit of Ark Foods) located at First Floor, Property No-21/31, Block-L, Mall Road, Civil Line, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. This Fire Safety Certificate is valid only for restaurant at first floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
4. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of firefighting system.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

### INSPECTION REPORT

1. Name & address of the building : M/s Gola Sizzlers (A Unit of Ark Foods) at 21/31, Block-L, First Floor, Mall Road, Civil Line, Delhi-110054.
2. Type of Occupancy : Assembly (Restaurant)
3. Composition of building : Basement, Ground & 03 Upper Floors but restaurant running at first floor only basement-vacant, ground floor- other restaurant, 2<sup>nd</sup> & 3<sup>rd</sup> floor- vacant
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 26.10.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mr. Ankush Kapoor
10. Year of Construction : 2023
11. Applicant's letter No. : Online MHA Portal I D No. 2023102117598 Dated:23.10.2023
12. Covered area-110sqm

	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC-2016 requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 NA NA	09m approx... NA NA	MR NA NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 NA	02 NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.50m each NA	02m & 1.50m NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.50m each	02m & 1.50m	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors (first floor)</li> </ul>	NA Required	NA Provided	NA MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI marking</li> </ul>	04nos ABC/Co2 Yes	04nos ABC-04 Provided	MR MR MR



6	<b>First-Aid Hose Reels.</b>				
	• Total numbers on each floor	01	Provided	MR	
	• Length of hose reel hose	30m	30m	MR	
	• Nozzle diameter	5mm	5mm	MR	
7	<b>Automatic fire detection and alarming system.</b>				
	• Type of detectors	Required	Provided	MR	
	• Location of Main Panel	Required	First floor	MR	
	• Location of Repeater Panel	NA	NA	NA	
	• Alternate source of power	NA	NA	NA	
	• Hooters' Location	NA	NA	NA	
8	<b>MOEFA</b>	Required	Provided	MR	
9	<b>Public Address System.</b>	NA	NA	NA	
10	<b>Automatic Sprinkler System.</b>				
	• Basement	NA	NA	NA	
	• Upper Floor	NA	NA	NA	
	• Sprinkler above false ceiling	NA	NA	NA	
11	<b>Internal Hydrants</b>				
	• Size of riser/down-comer	100mm	Provided	MR	
	• Number of hydrants per floor	01	01	MR	
	• Hose Box	01	01	MR	
12	<b>Yard Hydrants.</b>				
	• Total number of hydrants	NA	NA	NA	
	• Hose Box	NA	NA	NA	
13	<b>Pumping Arrangements.</b>				
	• Ground Level	➤ Discharge of main Pump	NA	N/A	NA
		➤ Head of Main pump	NA	N/A	NA
		➤ Number of main pumps	NA	N/A	NA
		➤ Jockey Pump out put	N/A	N/A	N/A
		➤ Jockey pump head	N/A	N/A	N/A
		➤ Standby Pump out put	N/A	N/A	N/A
		➤ Standby Pump Head	N/A	N/A	N/A
		➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
		➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	➤ Discharge of pump	450lpm	450lpm	MR
		➤ Head of the pump	40m	40m	MR
		➤ Power Supply	Required	Provided	MR
		➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>				
	• Underground tank capacity	➤ Draw-off connection	NA	NA	NA
		➤ Fire service inlet	NA	NA	NA
		➤ Access to tank	Required	Provided	MR
		➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity		20,000ltr	Provided	MR
		Required	Provided	MR	
15	<b>Exit Signage.</b>				
		Required	Provided	MR	

16	Provision of Lifts.	Provided but not working order		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA


Note:-

- (a) The total covered area of the first floor Restaurant is 202sqm (Approx.) including seating area, toilet area, kitchen area,
- (b) As per the NBC Part IV, the number of occupants comes out to be approx. 112 person's i.e. (202/1.8=112)





The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no. F6/DFS/MS/2023/EH/576 dated: 20.10.2023 have been compiled by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Dy. Chief Fire Officer (NW)

  
 Signature of the Inspecting Officer  
 Name :- C.L. Meena  
 Designation:- Asst. Div. Officer (RN)

JFOI.....5.0  
 Dated.....23/10/2023

  
 22/10  
  
  
 30/10/2023  
 Director  
  
 29/10/23

  
 AD/RN