

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F.6/DFS/MS/2023/Petrol/WZ/512

Dated 02/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Leo Filling Station** located at **Pocket-E, Sector-18, Rohini, Delhi-110085** comprised of **Single Story Building** owned/ occupied by **Leo Filling Station** was issued NOC by this department for storage of petroleum Class "A" & "B" vide this office letter no. **F.6/DFS/MS/2020/Petrol/WZ/412 dated 12.10.2020** and the Filling Station have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **11.10.2023** in the presence of **Mr. Ajay Kumar (Manager)** and that the building/ premises is **fit for storage of Petroleum Class A & B** with effect from 02/11/2023 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/11/2023 at New Delhi by

  
**(Gul Garg)**  
**DIRECTOR**  
Ph: 011-23414000

Copy to :-

1. Mrs. Ruchika Gupta (Partner), Leo Filling station, Pkt-E, Sec-18, Rohini, Delhi-110085.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

## INSPECTION REPORT

1. Name & address of the building	Leo Filling Station, Pocket-E, Sector-18, Rohini, Delhi-110085
2. Type of Occupancy	Petroleum Filling Station Group J
3. Type of Case	Renewal (Single story building)
4. Details of Previous NOC	F.6/DFS/MS/2020/Petrol/WZ/412 dated 12.10.2020
5. Fire Safety directives letter No	NBC Part-IV
6. Date of inspection	11.10.2023
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers From the building side	Mr. Ajay Kumar (Manager)
9. Year of Construction	2001
10. Applicant's letter No.	Online mail dated 03.10.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	12mtr	30m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>2. Number of staircases</b>			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	<b>3. Width of staircases</b>			
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	<b>4. Protection of exits</b>			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	<b>d. No. of continuous staircases to terrace</b>	NA	NA	NA
	<b>e. Width of Corridor</b>	NA	NA	NA
	<b>f. Door Size</b>	1.0m	1.0m	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	<b>Fire Extinguishers</b>			
	• Total numbers	04nos	10nos	MR
	• Types	ABC/CO2	6 trolley 75kg. each 04 ABC 10kg.	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	<b>Automatic fire detection and alarming system</b>			

	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Ground &amp; Upper Floors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
15.	<b>Exit Signage.</b>	NA	NA	NA
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Communication In lift Car</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			

A/N/N/7	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
<b>Fire Control Room</b>				
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	Fire buckets filled with sand, No smoking boards were found displayed in Hindi & English. No loose electric wiring were seen in premises & Co2 flooding system found provided		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2020/Petrol/WZ/412 dated 12.10.2020 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*[Signature]*  
16/10/23

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

Dy.CFO(WZ)

Where is form 'J' & 'K' ?

*[Signature]*  
16/10

ADO(Rohini)

Form J & K obtained from applicant is enclosed opposite at CP/2/23.

237  
16/10/23

*[Signature]*  
26/10/23

Dy.CFO(WZ) *[Signature]* 27/10

237  
27/10/23

CP/2/23  
25/10/2023  
*[Signature]*  
27/10/23