



No.F6/DFS/MS/Ind/NDZ/2023/ 508

Dated: 01/11/2023

FIRE SAFETY CERTIFICATE

Certified that the **Tata Motors Ltd.** located at **Plot No. 1, Gazipur, Patparganj, Delhi-110096**, owned / occupied by **Tata Motors Ltd.**, comprised of **Basement, Ground, First & Second Floor** only was issued FSC vide letter No. **F6/DFS/MS/Ind/2020/NDZ/05** Dated **06/01/2020**. The premises was re-inspected by the officer concerned of this department **23.10.2023** in presence of **Sh. Tarunmeet Singh (Head)** and observed that all the **Fire Prevention and Fire Safety** arrangements provided in the premises found in **good working condition**. The premises have therefore deemed complied with **rule 33** of the **Delhi Fire Service Rule, 2010** and that the building is fit for occupancy class **"Industrial" (Group-G)** with effect from **01/11/2023** for a period of **three years** in accordance with **rule 36** unless renewal under **rule 37** or sooner cancelled under **rule 40** and subject to compliance of the conditions under **rule 38** of the **DFS rules, 2010**.

Issued on 01/11/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
e/c @

Copy to:-

1. The Manager, Tata Motors Ltd., Plot No. 1, Gazipur, Patparganj, Delhi-110096.
2. The Executive Engineer (Bldg.) HQ, MCD, Udyog Sadan, 419, Patparganj Ind. Area, Delhi-92.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used strictly as per Building By-Laws 1983
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Tata Motors Ltd., Plot No. 1, Ghazipur, Patparganj, Delhi -96		
2	Building is comprised of	Basement, Ground, First & Second Floor only.		
3	Type of occupancy	Industrial		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/Ind/2020/NDZ/05 Dated 06/01/2020		
6	Fire safety direction letter no.	BBL		
7	Date of inspection	23.10.2023		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer From the building side	Sh. Tarunmeet Singh (Head)		
10	Year of construction	1988		
11	Applicant's letter no.	Outdoor Diary no. 7400 dated 16.10.2023		
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements NBC	Provide at site	Remarks MR/NMR
1	Access to Building			
	A Road width	12 m	Provided	MR
	B Gate width	4.5 m	Provided	MR
	C Width of internal roads	6.0 m	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	A No. of staircase:			
	a) Upper floor	02 nos.	02 nos. ✓	MR
	b) Basements	02 nos.	02 nos.	MR
	B Width of the staircase:			
	a) Upper floors	1.25 m	1.35 m each ✓	MR
	b) Basements	1.25 m	1.26 m each ✓	MR
	C Protection of Exits			
	a) Fire check door	Required	Provided	MR
	b) Pressurization	NA	NA	NA
	D No. of continuous staircase to terrace:	01 no.	01 no. ✓	MR
	E Width of the corridor	1.5 mtrs	Provided ✓	MR
	F Door size	1.0 mtr	Provided	MR
3	Compartmentation:			
	A Fire check doors	Required	Provided ✓	MR
	B Sealing of horizontal & vertical opening	Required	Provided ✓	MR
	C Fire rating of shaft doors	02 hrs.	Provided ✓	MR
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke management System:			
	A Basements	Required	Provided ✓	MR
	B Upper floors	NA	NA	NA
5	Fire extinguishers			
	A Total numbers	40 nos.	50 nos.	MR
	B Types	CO ₂ , ABC	CO ₂ , ABC	MR
	C ISI marking	ISI marked	Provided	MR

(u)

6	First Aid Hose Reel			
A	Total no. at each floor	01 no.	01 no.	MR
B	Length of hose reel	30 mtrs	30 mtrs	MR
C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS)			
A	Type of detectors	N/A	Heat & Smoke	N/A
B	Location of main Panel	Security Room	Provided	MR
C	Location of repeater panel	Security Room	Provided	MR
D	Alternate power source	Battery & DG Set	Provided	MR
E	Hooter's location	Staircase	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
A	Basement	Required	Provided	MR
B	Upper floor	N/A	Provided	N/A
C	Sprinklers above false ceiling	N/A	Provided	N/A
11	Internal Hydrants			
A	Size of the riser/down comer	N/A	Provided	N/A
B	No. of hydrants per floor	N/A	Provided	N/A
C	Hose box	N/A	Provided	N/A
12	Yard Hydrants			
A	Total no. of hydrants	NA	10 nos.	NA
B	Hose box	NA	10 nos.	NA
13	Pumping arrangements			
A	Ground Level			
a)	Discharge of main pump	N/A	2850 LPM	N/A
b)	Head of main pump	N/A	70 mtrs	N/A
c)	Number of main pumps	N/A	01 no.	N/A
d)	Jockey pump out put	N/A	180 LPM	N/A
e)	Jockey pump head	N/A	70 mtrs.	N/A
f)	Standby pump out put	N/A	2850 LPM	N/A
g)	Standby pump head	N/A	70 mtrs.	N/A
h)	Auto starting / Manual stopping	Required	Auto	MR
i)	Pump house access	NA	NA	NA
B	Terrace Level			
a)	Discharge of pump	900 LPM	Provided	MR
b)	Head of terrace pump	40 mtrs	Provided	MR
c)	Power supply	Required	Provided	MR
d)	Auto starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting			
A	Underground tank capacity	2,00,000 Ltrs.	2,00,000 Ltrs.	MR
B	Draw off connection	Required	Provided	MR
C	Fire Service Inlet	Required	Provided	MR
E	Access to tank	Required	Provided	MR
D	Overhead tank capacity	10,000 Ltrs.	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of lift			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Fireman switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply	NA	NA	NA

18 Refuge Area				
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19 Fire Control Room				
A	Fire Detection System panel	NA	Provided	NA
B	Flow switch panel	NA	Provided	NA
C	P A system panel	NA	Provided	NA
D	Battery backup	NA	Provided	NA
E	Building floor plan	NA	NA	NA
20 Special Fire Protection for special risk if any				
A	Special Fire Protection system for Protection of Special Risk, if any	NA	NA	NA

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/Inds/2023/NDZ/708 dated 12.04.2023 by this department have been rectified by the management.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Director of Education the FSC issued vide letter no. F6/DFS/MS/Ind/2020/NDZ/05 Dated 06/01/2020 is recommended to be renewed.



25/10/2023

Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (L.N)

~~Dy. CFO (NDZ)~~

~~Signature~~
26/10/23

~~C.F.O.~~

where is DO

~~Signature~~
27/10/2023

~~Dy CFO (NDZ)~~

Sir,

As per orders of Competent Authority on the file of Saeedar Patel Modern School, Ghazoli, Mayapuri vihar - III, Delhi -96 (copy placed at C/56), files are to be put up directly to DyFO (NDZ). Submitted please.

~~CFO.~~

~~Signature~~
27/10/2023

~~Director~~

~~Signature~~
27/10/23