



FIRE SAFETY CERTIFICATE

Certified that **The Devils Night Lounge and Bar** located at Shop No.01A, F-37,41, 42, 43, & 44 first floor Star City, Mayur Vihar, Delhi-110091, running at First floor only in a building comprised of Basement + Ground + 03 Upper floor, owned/occupied by **The Devils Night Lounge and Bar** was issued FSC vide letter no. F6/DFS/MS/EH/NDZ/2018/1592 dated 09/07/2018 (in the name of M/s Mirror reloaded restaurant). The premises was re-inspected by the officer concerned of this department on dated 21/10/2023 in the presence of Mr. Deepak Chauhan (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy "Assembly" (Group D) Eating House (Restaurant at First floor only) and valid up to 31/03/2026 (Three years) in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 30/10/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE


Copy to:-

1. The Manager, The Devils Night Lounge and Bar located at Shop No.01A, F-37,41, 42, 43, & 44 first floor Star City, Mayur Vihar, Delhi-110091.
2. Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.e.f. - MHA portal ID - 2023092716497 dated -28/09/2023.

Conditions for the validity of Fire Safety Certificate:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used strictly as per Building By-Laws 1983.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	The Devils Night Lounge and Bar located at Shop No.01A, F-37,41, 42, 43, & 44 first floor Star City, Mayur Vihar, Delhi-110091.		
2	Building is comprised of	Basement + Ground + 03 upper floors only. (Eating House is First Floor only)		
3	Type of occupancy	Eating House / Bar		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/EH/NDZ/2018/1592 dated 09/07/2018 (in the of M/s Mirror Reloaded restaurant).		
6	Fire safety direction letter no.	NBC Part-IV		
7	Date of inspection	21.10.2023		
8	Name of the inspecting officers	Yashwant Singh Meena (ADO/LN)		
9	Name of the designation of officer From the building side	Mr. Deepak Chauhan (Manager)		
10	Year of construction	2007		
11	Applicant's letter no	Application no. 2023092716497 dated -28/09/2023		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	a	Road width	12 mtrs	13 mtrs / MR
	b	Gate width	4.5 mtrs	6.0 mtrs MR
	c	Width of internal road	6.0 mtrs	6.0 mtrs MR
2	Number, Width, Type and Arrangement of Exits			
	A	Number of staircases		
		a	Upper floor	02 nos. 02 nos. MR
		b	Basement	N/A N/A N/A
	B	Width of staircases		
		a	Upper floor	1.25 Mtr 1.25 mtr / MR
		b	Basement	N/A N/A N/A
	C	Protection of exits		
		a	Fire check door	Required Provided MR
		b	Pressurization	Required Provided MR
	D	No. of continuous staircases to terrace		
	E	Width of corridor		
	F	Door size		
			2.5 mtrs 2.5 mtrs MR	
			2.0 mtrs 2.0 mtrs. MR	
3	Compartmentation			
	a	Fire check door		
	b	Sealing of electrical shafts		
	c	Fire rating of shaft door		
	d	Water curtain		
	e	Fire dampers		
			Required Provided MR	
			Required Provided MR	
			02 hrs. 02 hrs. MR	
			N/A N/A N/A	
			N/A N/A N/A	
4	Smoke Management System.			
	a	Basement		
	b	Upper floor		
			NA NA NA	
			12 a/c per hour 12 a/c per hour MR	

W

5.	Fire Extinguisher				
	a	Total numbers	06 nos.	06 nos.	MR
	b	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	c	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels. Provided In the Mall				
	a	Total numbers of each floor	01 no.	01 no.	MR
	b	Length of hose reel hose	30 Mtrs.	30 Mtrs.	MR
	c	Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system.				
	a	Type of detectors	Heat & Smoke	Provided	MR
	b	Location of main panel	Control Room	Basement	MR
	c	Location of repeater panel	Reception	Provided	MR
	d	Alternate source of power	Required	Provided	MR
	e	Hooter	Strategic Location	Provided	MR
8	MOEFA		Required	Provided	MR
9	Public address System.		N/A	N/A	N/A
10	Automatic Sprinkler System.				
	a	Basement	N/A	N/A	N/A
	b	Upper floors	Required	Provided	MR
	c	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants				
	a	Size of riser	100 mm	100 mm	MR
	b	Number of hydrants per floor	01 no.	01 no.	MR
	c	Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.				
	a	Total number of hydrants	NA	NA	NA
	b	Hose Box	NA	NA	NA
13	Pumping Arrangements.				
	A	Ground Level			
	a	Discharge of main Pump	4500 LPM	4500 LPM	MR
	b	Head of Main Pump	50 mtrs	50 mtrs	MR
	c	Number of main pumps	02 nos.	02 nos.	MR
	d	Jockey pump out put	450 LPM	450 LPM	MR
	e	Jockey pump head	50 mtrs	50 mtrs	MR
	f	Standby pump out put	4500 LPM	4500 LPM	MR
	g	Standby pump head	50 mtrs	50 mtrs	MR
	h	Auto starting /manual stopping	Required	Auto	MR
	i	Pump House Access	Required	Provided	MR
	B	Terrace Level			
		All above pumps on terrace			
	a	Discharge of pump	NA	NA	NA
	b	Head of the Pump	NA	NA	NA
	c	Power supply	NA	NA	NA
	d	Auto Starting of pump	NA	NA	NA

e Devils Night Lounge and Bar located at Shop No.01A, F-37 41, 42, 43, & 44 first floor Star City, Mayur Vihar, Delhi-110091.

W

CP




14	Captive Water Storage for Fire Fighting.				
	a	Underground tank capacity	2,00,000 Ltr	2,00,000 Ltr	N/A
	b	Draw-off connection	Required	Provided	MR
	c	Fire service inlet	Required	Provided	MR
	d	Access to tank	Required	Provided	MR
	e	Overhead Tank capacity	2,50,000 ltrs.	2,50,000 ltrs	MR
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	a	Pressurization of Lift Shaft	Required	Provided	MR
	b	Pressurization of Lift lobby	Required	Provided for Basement	MR
	c	Communication in lift car	Required	Provided	MR
	d	Firemen's grounding switch	Required	Provided	MR
	e	Lift Signage	Required	Provided	MR
17	Standby power supply		NA	NA	NA
18	Refuge Area.				
	a	Total area	NA	NA	NA
	b	Location	NA	NA	NA
19	Fire Control Room				
	a	Detector system panel	Required	Provided	MR
	b	Flow switch panel	Required	Provided	MR
	c	PA system panel	Required	Provided	MR
	d	Battery backup	Required	Provided	MR
	e	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:		NA	Provided in LT & HT Panels	MR

Note:- Previous restaurant was running name of Maini's Green Leaf at same address now owner and name of restaurant has been changed.

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2018/1592 dated 09/07/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


 25/10/2023
 Signature of the Inspecting Officer
 Name: Yashwant Singh Meena
 Designation: ADO (L.N)

Dy. CFO (NDZ)

 C.F.O.

 27/10/2023
 Director

 24/10/2023

ADO L.N

Updated 30/10/23