

C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/School/2023/SZ/ 784

Dated: 03/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Adarsh Public School running at ground plus three upper floors in a building comprised of basement, ground plus three upper floors located at C-Block, Vikaspuri, New Delhi -110018, owned/occupied by Adarsh Public School was issued Fire Safety Certificate by this department vide letter F6/DFS/MS/School/2020/SZ/549 dated 11/12/2020. The School building was re-inspected by the officer concerned of this department on 27/10/2023 in the presence of Sh. Prashant Sahgal (Chairman) of the school and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Group B 'Educational Building' for with effect from 03/11/2023 for a period of three years, in accordance with the rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on..... 03/11/2023 ..... at New Delhi

  
(Atul Garg)  
Director  
Delhi Fire Service  


To,

The Chairman, Adarsh Public School, C-Block, Vikaspuri, New Delhi-110018.

Copy to:-

- 1 Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. **Basement shall be used as per the building bye laws.**
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/14

1. Name & address of the building : Adarsh Public School, C-Block, Vikaspuri,  
New Delhi -110018
2. Building is comprised of : Basement+ Ground plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/School/2020/SZ/549 dated 11/12/2020
6. Fire Safety directive letter No : N/A
7. Date of Inspection : 27/10/2023
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of Officer  
from the building side : Sh. Prashant sahal (Chairman)
10. Year of Construction : 1990-1991
11. Applicant's letter No : Nil dated 17/10/2023

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement NBC Part IV	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	06 mtrs.	06 mtrs.	MR
	• Gate width	4.5 mtrs	06,3.66 & 2.2 mtrs	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	03 no.	03 no.	MR
	• Basement	03 Nos in Ist,02 in IInd & 01 no. in IIIrd	03 Nos in Ist,02 in IInd & 01 no. in IIIrd	MR
	B. Width of Staircases			
	• Upper Floor	1.5 M & 75 M	1.25,1.20,1.21 m & 92 m (GF to FF)	MR
	• Basement	1.5 M & 75 M	1.90,1.30,&1.20 m in Ist,1.07 & 92 m in IInd & 1.18m III rd	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 no.	01 no.	MR
	e. Width of Corridor	1.50 mtr.	2.40 M n GF & FF&2.40 & 90M in IIIrd Floor	MR old case
	f. Door Size class	01 mtr.	01 mtr.	MR
	g. Number of Door	02 no.	02 no.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Exhaust Fans are provided	MR
	• Upper floor	Required	Natural ventilation	N/A
05.	Fire Extinguishers.			
	• Total numbers	30 nos.	30 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

h

06	First-aid-Hose Reels.			
	Total numbers on each floor	02 No.	02 No.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	100 mm	MR
	• Number of hydrants per floor	N/A	Two	MR
	• Hose Box	N/A	One	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM.(02 no.s)	900 LPM & 180 LPM Provided	MR
	➤ Head of the Pump	40 mtr <sup>+</sup>	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	One (02 way)	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 Ltr.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

W/16

17	Standby power supply	N/A	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection

In View of the deemed compliance of the minimum standards of fire prevention and fire safety required under the rules the fire Safety Certificate issued vide letter No F6/DFS/MS/School/2020/SZ/549 dated 11/12/2020 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*R.K. Yadav*  
 Signature of the Inspecting Officer  
 Name : R.K. Yadav  
 Designation : ADO (JKP)

DO(South West) *[Signature]*  
 31/10/23

CFO (S2) *[Signature]*  
 01/11/2023

Director *[Signature]*  
 02/11/23

*NSey*