



C 50

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2023 / School / WZ / 770

Dated: 31/10/2023

FIRE SAFETY CERTIFICATE

Certified that the **Aadharshila Vidyapeeth** located at **CD Block, Pitampura, Delhi-110034**, comprised of 03 Blocks; Block- 1 is comprised of Basement, Ground plus three upper floors (Basement floor is closed & not in use), Block- 2 is comprised of Ground plus two upper floors and Block- 3 is comprised of Basement, Ground plus three upper floors, owned/occupied by **Aadharshila Vidyapeeth** was issued FSC by this department vide letter No F6/DFS/School/WZ/2020/313 dated 28.08.2020. The premise was re-inspected by the officer concerned of this department on 14.09.2023 in the presence of **Smt. Priti Saxena (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirement under rule 33 of the Delhi Fire Service Rule, 2010 and fire safety requirements in accordance with Director of Education Circular Dated 17/01/2005 and that the building/ premise is fit for occupancy **Group B Educational(Except Basement of Block-1)** with effect from **31.10.2023**..... for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **31.10.2023**..... at New Delhi, by

(Anil Garg)
Director
Delhi Fire Service

Copy to :-

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Aadharshila Vidyapeeth located at CD Block, Pitampura, Delhi-110034.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. Basement of Block 1 Shall not be used for any purpose..
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Aadharshila Vidyapeeth located at CD Block, Pitampura, Delhi-110034.
2. Type of Occupancy : Educational
3. Building Comprised of : 03 Blocks (Block 1 & Block 3- Basement, Ground + Three Upper Floors)
(Block 2- Ground + Two upper floors).
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/School/WZ/2020/313 Dated 28/08/2020
6. Fire Safety directives letter No : DOE Circular No. 262-362 dated 17/01/2005 & As Per N-26
7. Date of inspection : 14/09/2023
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Smt. Priti Saxena (Principal)
10. Year of Construction : 2004
11. Applicant's letter No. : E Mail id dated 30/08/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	5 m	MR(old case)
	• Gate width	4.5 m	3 m	MR(old case)
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Block 1- 01 Block 2- 01 Block 3- 02	Block 1- 02 Block 2- 01 Block 3- 03	MR
	• Basements	Block 1- 02 Block 3- 02	Block 1- 01 Block 3- 04	MR(Basement of Block 1 is sealed)
	b. Width of staircases			
	• Upper Floor	1.50 m each	Block 1- 1.25 m & 1.4 m Block 2- 1.55 m Block 3- 1.62 m, 1.22 m & 1.4 m	MR
	• Basements	Block 1- 1.5 m & 1 m Block 3- 1.5 m & 1 m	Block 1- 1.25 m Block 3- 1.4 m×2, 1.8m & 1.24 m	MR(Basement of Block 1 is sealed)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Block 1 & 2- 01 Block 3- 02	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			

h

	• Total numbers	1@300 SQM	Provided	MR
	• Types	ABC/Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR
5.	First-Aid Hose Reels			
	• Total numbers on each floor	Block 1 & 2- 1 each Block 3- 02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	Type of detectors (in Auditorium)	Smoke	Provided	MR
	• Location of Main Panel	GF	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	Required in Auditorium	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	Block 3- 02 Block 1&2- 1 each	Provided	MR
	• Hose Box	Block 3- 02 Block 1&2- 1 each	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	Provided	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA

• Terrace level			
➤ Discharge of pump	900 lpm & 180 lpm	Provided	MR
➤ Head of the pump	50 m	Provided	MR
➤ Power Supply	Required	Provided	MR
➤ Auto Starting of pump	Required	Provided	MR
14. Captive Water Storage for fire fighting			
• Underground tank capacity	NA	100 KL	NA
➤ Draw-off connection	NA	Provided	NA
➤ Fire service inlet	NA	Provided	NA
➤ Access to tank	NA	Provided	NA
• Overhead Tank capacity	20,000 ltrs	Provided	MR
15. Exit Signage.	Required	Provided	MR
16. Provision of Lifts.			
• Pressurization of Lift Shaft	NA	NA	NA
• Pressurization of Lift lobby	NA	NA	NA
• Communication In lift Car	NA	NA	NA
• Fireman's Grounding Switch	NA	NA	NA
• Lift Signage	NA	NA	NA
17. Standby power supply	Required	Provided	MR
18. Refuge Area.			
➤ Total Area	NA	NA	NA
➤ Location	NA	NA	NA
19. Fire Control Room			
• Detector System Panel	NA	NA	NA
• Flow Switch Panel	NA	NA	NA
• PA System Panel	NA	NA	NA
• Battery backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA
20. Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Basement of Block 01 is sealed and shall not be used for any purpose.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 262-362 dated 17/01/2005, it is recommended to renew the Fire Safety Certificate issued vide letter no. F6/DFS/School/WZ/2020/313 dated 28/08/2020 under rule 35 of Delhi Fire Service Rules, 2010.

123
22/9/2023

A. H. (102)

22/9

20/9/23