

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2023/SZ/ 4253

Dated: 14/11/2023

To

Mr. O. M. Soman (Estate Manager)
Sahyog Building Flat Owners Association,
900, Siddharth Building,
96, Nehru Place, New Delhi 110019

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Sahyog Building No 58 at Nehru Place, New Delhi- 110019

Sir,

This has reference with letter, received through outdoor diary no 5178 dated 21/08/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 03/11/2023 in the presence of Mr. O. M. Soman and observed to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The Fire Check door found removed at some places.
2. Smoke management system not working in basement.
3. First aid hose reel nozzle found missing.
4. Automatic detection system provided but found nonfunctional.
5. Exit signage found removed.
6. Electrical meter install in the lift lobby area is not acceptable.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

0/11