

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/2023/SZ/College/27

Dated: 03/11/2023

FIRE SAFETY CERTIFICATE

Certified that **Jagan Nath Gupta Memorial Education Society** located at Sec-B-OCF, Pocket-9, Vasant Kunj, New Delhi having two Blocks both Comprised of Basement Ground plus Three Upper floors was issued FSC by this department vide letter F6/DFS/MS/SZ/2020/396 dated 05/10/2020. The premise was re-inspected by the officer concerned of this department on 27/10/2022 in the presence of Mr. Amit Kamra, (Admin Officer) and observed that the said premises have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy "**Education Building**" with effect 03/11/2023 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on 03/11/2023 at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. Dr. Amit Gupta, Jagan Nath Gupta Memorial Education Society located at Sec-B-OCF, Pocket-9, Vasant Kunj, New Delhi.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. The basement shall be used as per the provisions of UBBL 2016 /NBC Part- IV.
6. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Jagan Nath Gupta Memorial Education Society, Sec-B-OCF, Pocket-9, Vasant Kunj, New Delhi
2. Type of Occupancy : Class-B "Educational"
3. Type of Case : Renewal
4. Comprised of : 02 Block, A Block- Basement, Ground + 03 Upper floors & B-Block, Basement, Ground + 03 Upper floors
5. Details of Previous NOC : F6/DFS/MS/SZ/2020/396 dated 05/10/2020
6. Fire Safety directives letter No : F6/DFS/MS/BP/2014/338 dated 18/12/2014
7. Date of inspection : 27/10/2023
8. Name of Inspecting Officer : Sh. Rajesh Kumar, ADO (BCP)
9. Name and designation of officers
From the building side : Mr. Amit Kamra (Admin Officer)
10. Year of Construction : 2003 & 2014
11. Applicant's letter No. : Email dated 12/10/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9m 5m NA	Provided 02 Nos (05 & 4.85m) NA	MR MR (old) NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	2 Nos 2 Nos	02 Nos each block 02 Nos each block & 02 Ramp	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.5m 1.5m	A Block- 1.12m & 1.51m B Block- 1.52m & 1.24m A Block- 1.52m & 1.17m & ramp 03m & 3.05m B Block- 1.52m & 1.24m	MR MR MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required -NA-	Provided -NA-	MR -NA-
	d. No. of continuous staircases to terrace	Required	04 Nos Provided	MR
	e. Width of Corridor	1.50 mtr	Provided	MR
	f. Door Size	Required	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required -NA- -NA- -NA-	Provided Provided -NA- -NA- -NA-	MR MR -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Provided -NA-	MR -NA-
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	18 No's ABC/W. CO ₂ /CO ₂ ISI	18 No's 10/05/03 No's Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 nos at each 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Ground Floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01 Nos	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01 Nos	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose Box 	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	-NA-	1620 LPM	-NA-
		-NA-	60m	-NA-
		-NA-	01 Nos	-NA-
		-NA-	180 LPM	-NA-
		-NA-	60m	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 LPM	Provided	MR
		40 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	50,000 ltrs	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Draw-off connection 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	15,000 ltrs	20,000 ltr	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 			
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication In lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift Signage 	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location 	-NA-	-NA-	-NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Flow Switch Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> PA System Panel 	-NA-	-NA-	-NA-

2/19

-NA-
-A-

	<ul style="list-style-type: none"> Battery backup Building Floor Plans 	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/SZ/2020/396 dated 05/10/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 may be issued.

Accordingly DFA is put up for approval and signature please.

[Handwritten Signature]
31/10/23

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

~~DO (SD)~~

Mull
30/10/23

Chf. Insp.
31/10/2022

Director
31/10/22

F.P. 1

ADO/BCP

As approved, F.S. letter is put up for your signature pl

Director
31/10/23
m

1/14
01/11/2023