

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6/DFS/MS/2023/School/WZ/ 773

Dated: 31/10/2023

FIRE SAFETY CERTIFICATE

Certified that the M. C. Primary Girls School, Shahabad Daulatpur, Delhi-42, comprised of Ground floor 04 nos. pucca rooms only owned/occupied by M. C. Primary Girls School was granted FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2020/321 dated 01.09.2020. The premises was re-inspected by the officer concerned of this department on 16.10.2023 in the presence of Mr. Virender Singh (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ...31.10.2023.. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ...31.10.2023..... at New Delhi



(Atul Garg)
DIRECTOR
Ph; 011-23414000



Copy to: -

1. The Commissioner, DMC, Sector-5, Rohini, New Delhi-110085.
2. The Principal, M. C. Primary Girls School, Shahabad Daulatpur, Delhi-42.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	M. C. Primary Girls School, Shahabad Daulatpur, Delhi-42			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (Ground floor -04 no's pucca rooms only)			
4. Details of Previous NOC	F.6/DFS/MS/School/WZ/2020/321 dated 01.09.2020.			
5. Fire Safety directives letter No	Director of Education dated 01.03.2011.			
6. Date of inspection	16.10.2023.			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Mr. Virender Singh (Principal)			
9. Year of Construction	2006			
10. Applicant's letter No.	OD No.6378 dated 21.09.2023.			
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOB Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	4.5m	3.4m	MR(Old case)
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	e. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	f. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.20m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	02nos.	02nos.	MR
	• Types	ABC/CO2	ABC-02nos.	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA

N/19

	<ul style="list-style-type: none"> • Alternate source of power • Hooters' Location 	NA	NA	NA	NA
8.	MOEFA	NA	NA	NA	NA
9.	Public Address System	NA	NA	NA	NA
10.	Automatic Sprinkler System				NA
	<ul style="list-style-type: none"> • Basement • Ground & Upper Floors • Sprinkler above false ceiling 	NA	NA	NA	NA
11.	Internal Hydrants				NA
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA	NA
12.	Yard Hydrants				NA
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA	NA
13.	Pumping Arrangements				NA
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➢ Discharge of main Pump ➢ Head of Main pump ➢ Number of main pumps ➢ Jockey Pump out put ➢ Jockey pump head ➢ Standby Pump out put ➢ Standby Pump Head ➢ Auto Starting/Manual Stopping ➢ Pump House Access • Terrace level <ul style="list-style-type: none"> ➢ Discharge of pump ➢ Head of the pump ➢ Power Supply ➢ Auto Starting of pump 	NA	NA	NA	NA
14.	Captive Water Storage for fire fighting				NA
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➢ Draw-off connection ➢ Fire service inlet ➢ Access to tank • Overhead Tank capacity 	NA	NA	NA	NA
15.	Exit Signage.				
16.	Provision of Lifts.				NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA	NA
17.	Standby power supply				
18.	Refuge Area.				NA
	<ul style="list-style-type: none"> ➢ Total Area ➢ Location 	NA	NA	NA	NA
19.	Fire Control Room				NA
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel 	NA	NA	NA	NA

Org

• Battery backup		NA	NA
• Building Floor Plans		NA	NA
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measure as required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/School/WZ/2020/321** dated **01.09.2020** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Signature] 22/10/23
 Signature of the Inspecting Officer
 Name **Ajay Kumar Sharma**
 Designation **ADO(Rohini)**

Dy. CFO(WZ)
[Signature]

[Signature]
 25/10

[Handwritten notes]
 11/10/2023

CFO *[Signature]*
 25/10/2023

Director *[Signature]*
 26/10/23

ADO/Rohini *[Signature]*

Fr letter to put up for
 kind perusal and signature
 please.

Director *[Signature]*
 Nayle

[Signature]
 27/10/23