

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2023/SZ/ 785

Dated: 03/11/2023

FIRE SAFETY CERTIFICATE

Certified that the Oxford Sr. Secondary School running at ground plus three upper floors in a building comprised of two basements, ground floor plus three upper floors having total 113 rooms (Including Class Rooms, Offices, Sci. Lab, Comp. Lab, Library & Sports Room etc.) located at E-Block, Vikaspuri, New Delhi-110018, owned/occupied by Oxford Sr. Secondary School was issued Fire Safety Certificate by this department vide letter F.6/DFS/MS/School/2020/SZ/473 dated 05/11/2020. The School building was re-inspected by the officer concerned of this department on 27/10/2023 in the presence of Sh. Suraj Prabhakar (Manager) and found that the building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....03/11/2023..... at New Delhi.

(Signature)
Director
Delhi Fire Service

Copy to:-

1. The Manager, Oxford Sr. Secondary School, E-Block, Vikaspuri, New Delhi-110018
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. **Basement shall be used as per the building bye laws.**
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Oxford Sr. Secondary School, E-Block, Vikaspuri, New Delhi-18.
2. Building comprised of : Two separate Basements, Ground floor plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2020/SZ/473 dated 05/11/2020
6. Fire Safety directives letter No : N/A
7. Date of inspection : 27/10/2023
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Suraj Prabhakar (Manager)
10. Year of Construction : 1994-95
11. Applicant's letter No. : OSSS/VP/1552/2023 dated 19/10/2023


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 6 mtrs 4.5 mtrs N/A	12 mtrs 04 & 04 mtrs N/A	MR MR, being old case N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	04 No's 04 No's	04 No's 04 No's	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 M 1.50 M	3X1.80 M & 1X1.33 M 1.60 & 1.57 M, 1.90 & .75 M	MR, being old case MR, being old case
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
	f. Door Size			
		Required	Three	MR
		1.50M	2.40 & 2.50 M	MR
		1.0 M	1.12 M	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	Required	Exhaust fans are provided	MR
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	25 no.'s ABC/CO ₂ type ISI marked	Provided Provided ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	03 no.'s 30 mtrs 5 mm	Provided Provided Provided	MR MR MR



7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA			
9.	Public Address System			
		N/A	Provided	N/A
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	Three	N/A
	• Hose Box	N/A	Three	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	> Discharge of main Pump	N/A	N/A	N/A
	> Head of Main pump	N/A	N/A	N/A
	> Number of main pumps	N/A	N/A	N/A
	> Jockey Pump out put	N/A	N/A	N/A
	> Jockey pump head	N/A	N/A	N/A
	> Standby Pump out put	N/A	N/A	N/A
	> Standby Pump Head	N/A	N/A	N/A
	> Auto Starting/Manual Stopping	N/A	N/A	N/A
	• Pump House Access			
	• Terrace level			
	> Discharge of pump	Old case	450 LPM & 180 LPM provided	MR, being old case
	> Head of the pump	40 mtrs	Provided	MR
	> Power Supply	Required	Provided	MR
	> Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	50,000 ltrs	N/A
	> Draw-off connection	N/A	N/A	N/A
	> Fire service inlet	N/A	Provided	N/A
	> Access to tank	N/A	Provided	N/A
	• Overhead Tank capacity	Old case	5000 ltrs Provided	MR, being old case
15.	Exit Signage.			
		Required	Provided	MR
16.	Provision of Lifts.			
				No Lift
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply			
		N/A	Provided	N/A
18.	Refuge Area.			
	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A

N/A			
N/A	Fire Control Room		
N/A	• Detector System Panel	N/A	N/A
N/A	• Flow Switch Panel	N/A	N/A
N/A	• PA System Panel	N/A	N/A
N/A	• Battery backup	N/A	N/A
N/A	• Building Floor Plans	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2020/SZ/473 dated 05/11/2020 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of Inspecting Officer
 Name:- SR.K. Yadav
 Designation:- Asstt. Divisional Officer

D.O. (South West)

 31/10/23
 CFO (S2)
 High
 01/11/2023
 Director

 2/11/23
 N/Ses