



C-38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2023 / WZ / FH / 522

Dated: 07/11/2023

FIRE SAFETY CERTIFICATE

Certified that the Royal Arches Party Lawn located at G.T.K Road, Palla Bakhtawarpur Road, Alipur, Delhi-110036 comprised of Ground Floor only owned/occupied by Royal Arches Party Lawn was issued Fire Safety Certificate vide letter no. F6/DFS/MS/2020/430 dated 23/10/2020. The premise was re-inspected by the officer concerned of this department on 31/10/2023 in the presence of Sh. Sachin Behl and found that the said farm house building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building premise is fit for occupancy under "Mixed (Assembly & Residential)" with effect from ...07/11/2023 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/11/2023 at New Delhi by

(Atul Garg)

Director

Ph. 011-23414000

Atul

Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Copy to:-

1. The Assistant Engineer (Bldg.), Delhi Municipal Corporation, Narela Zone, Delhi.
2. M/s Royal Arches Party Lawn located at G.T.K Road, Palla Bakhtawarpur Road, Alipur, Delhi-110036.

INSPECTION REPORT

1. Name & address of the building : Royal Arches Party Lawn located at G.T.K Road, Palla Bakhtawarpur Road, Alipur, Delhi-110036.
2. Type of Occupancy : Mixed (Assembly & Residential)
3. Building Comprised : Ground Floor Only. (03 Guest Rooms at Ground Floor)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2020/430 dated 23/10/2020
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 31.10.2023
8. Name of Inspecting Officer : ADO R.K. Sinha
9. Name and designation of officers
From the building side : Sh. Sachin Behl
10. Year of Construction : 2010
11. Applicant's letter No. : E mail id Dated 25.10.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9 m 5 m NA	Provided Provided NA	MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA	NA NA NA NA	NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	1@300 SQM ABC & Co2 Yes	Provided Provided Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	Provided 30 m 5 mm	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA

M

N-17

Total
Locat
A

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	01	MR
	<ul style="list-style-type: none"> Hose Box 	01	01	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump house Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto starting of pump 	900 lpm	Provided	MR
		40 m	Provided	MR
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided, 125 KVA	MR
18.	Refuge Area.			

27

	Total Area	NA	NA	NA
	Location	NA	NA	NA
Fire Control Room				
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter number F6/DFS/MS/2023/WZ/4019 dated 17/10/2023.

Keeping in view of deemed compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2020/430 dated 23/10/2020 under rule 35 of the Delhi Fire Service Rules 2010.

[Handwritten Signature]
 ADO (BW)
 11/11/23

Signature of the Inspecting officer
 Name : Rajeev Kumar Sinha
 Designation : ADO/BW

[Handwritten Signature]
 Director (WZ)

by 2/11

cf to 3/11/2023

Director 3/11/23

A DO/BW Sir. P T letter re
 with to see them

[Handwritten Signature]
 ADO (BW)
 2/11/23

Director (P&S) 7/11/23

Sl. No. 322
 dated 2/11/2023