

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No: F.6/DFS/MS/School/WZ/2023/ 777

Dated: 01/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that the S. D. Public School, located at Satguru Ram Singh Marg, Kirti Nagar, New Delhi-110015, in a building comprised of ground plus two upper floors, Owned/occupied by S. D. Public School, was issued FSC vide letter No. F6/DFS/MS/School/WZ/2018/2363 dated 18/10/2018. The premises was re-inspected by the officer concerned by this department on 25/10/2023 in the presence of Sh. Shivam Tripathi (Admin.) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by DOE Circular No.- 262-362 dated 17/01/2005 and that the premises is fit for occupancy class "Educational" (Group-B), with effect from ..01/11/2023....for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below.

Issued on .01/11/2023... at New Delhi.

  
Atul Garg  
Director  
31/10 27/10/2023

Copy to: -

1. The Principal M/s S. D. Public School, located at Satguru P.am Singh Marg, Kirti Nagar, New Delhi-110015.
2. Director of Education, Old Secretariat, New Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



M/V

### INSPECTION REPORT

1. Name & address of the building	S. D. Public School Located at Satguru Ram Singh Marg, Kirti Nagar, New Delhi-110015.
2. Type of Occupancy	Educational (Ground + 02 upper floor)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/WZ/2018/2363 dated 18/10/2018
5. Fire Safety directives letter No	DOE Circular No.- 262-362 dated 17/01/2005
6. Date of inspection	25/10/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Shivam Tripathi (Admin.)
9. Year of Construction	2005-2006 (As per prev. inspection report dtd.- 05/10/2018)
10. Applicant's letter No.	Letter no. SDPS/KN/3495/2023 dated 11/08/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.50 mts	1.20 mtr x 1 & 1.30 mtr x 1	MR(old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5 m	Provided	MR
	g. Door Size	1 mtr	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	08	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

J

S



6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	Required 01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	Provided	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>			
		NA	NA	NA
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>			
		NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection. All the shortcomings issued by this department have been compiled by the management of school.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/WZ/2018/2363 dated 18/10/2018 renewal under Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

7/ADO/MN  
12/10/23

~~ADO (WZ)~~

~~Signature~~  
27/10/2023

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

FO/... 4/... 12/23  
led... 31/10/23

~~Signature~~  
31/10

CFD  
Signature  
31/10/2023

~~Director~~

~~Signature~~  
31/10/23

~~Signature~~