

c-27

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2023/790

Dated: 07/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Saraswati Vidyalaya, 4610/17, Daryaganj, New Delhi, comprised of A Block (Ground + 02 upper floors), Store (Ground + 01 upper floor) & Offices & library Block (Ground + 01 upper floor) was granted FSC by this department vide letter no.F6/DFS/MS/School/NDZ/2020/441 dated 22.10.2020. The premises was re-inspected by the officer concerned of this department on 31.10.2023 in the presence of Mrs. Shashi (Principal) and found that the building is comprised of A Block (Ground + 02 upper floors), Store (Ground + 01 upper floor) & Offices & library Block (Ground + 01 upper floor). The building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 17.01.2005. The building is fit for occupancy (Class-B) "Educational Building", A Block (Ground + 02 upper floors) & Offices & library Block (Ground + 01 upper floor) with effect from 07/11/2023.....for a period of three years subject to compliance of the condition mentioned below.

Issued on 07/11/2023.....at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000

**Copy to:-**

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Saraswati Vidyalaya, 4610/17, Daryaganj, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1	Name and address of the building:	Saraswati Vidyalaya, 4610/17, Daryaganj, New Delhi.
2	Type of occupancy with details of floors:	<b>Educational Building (Group-B)</b> School Building have divided into 3 blocks <b>A Block - (Ground + 02 upper floor)</b> <b>Store - (Ground + 01 upper floor)</b> <b>Offices &amp; Library Block - (Ground + 01 upper floor)</b>
3	Type of case:	Renewal (Old Case)
4	Details of previous FSC:	F6/DFS/MS/School/NDZ/2020/441 dated 22.10.2020
5	Fire safety directives no.:	NA
6	Date of inspection:	31.10.2023
7	Name of the inspecting officer:	Sumit Kumar, ADO (SPM)
8	Name and designation of the officer from the building side:	Mrs. Shashi (Principal)
9	Year of construction:	1932
10	Reference letter no.:	Letter no. SV/2023-24/1170 dated 22.09.2023

S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	As per Education Circular no. 262-362 dated 17.01.2005	Provide at site	Remarks MR/ NMR
-------	--	--	-----------------	-----------------

<b>1 Access to Building</b>				
A	Road width	06 mtrs.	06 mtrs.	MR
B	Gate width	NA	NA	NA
C	Width of internal roads	NA	NA	NA

<b>2 Number, Width, Type &amp; Arrangement of Exits</b>				
<b>A No. of Staircase:</b>				
	a) Upper floor	<b>A Block- 02 nos.</b> Offices & library block - 02 nos.	<b>A Block - 03 nos.</b> Offices & library block - 02 nos.	MR
	b) Basements	NA	NA	NA
<b>B Width of the Staircase:</b>				
	a) Upper floor	<b>A block - 1.50 mtr.</b> <b>Offices &amp; library block - 1.5 mtr</b> (If staircase width is less than 1.5 m additional staircase of 0.75 m is required)	<b>A block - 1.25, 1.19 mtr. &amp; 1.05 mtr.</b> <b>Offices &amp; library block - 1.14 &amp; 1.17 mtrs.</b>	MR
	b) Basements	NA	NA	NA
<b>C Protection of Exits</b>				
	a) Fire check door	NA	NA	NA
	b) Pressurization	NA	NA	NA
D	No. of continuous staircase to terrace:	01 nos.	01 nos.	MR
F	Width of the corridor	NA	NA	NA
E	Door size	1 mtr.	1 mtr.	MR

<b>3 Compartmentation:</b>				
A	Fire check doors	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft doors	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA

<b>4 Smoke management System:</b>				
A	Basements	30 ACPH	NA	NA
B	Upper floors	12 ACPH	Natural	MR

<b>5 Fire extinguishers</b>				
A	Total numbers	04 nos.	05 nos.	MR
B	Types	Co2 & ABC	Provided	MR
C	ISI marking	Required	Provided	MR

<b>6</b>	<b>First Aid Hose reel</b>			
A	Total no. at each floor (each block)	01 nos.	01 nos.	MR
B	Length of Hose Reel	Co2 & ABC	Co2 & ABC	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarm System (ADAS)</b>			
A	Type of Detectors	NA	NA	NA
B	Location of main Panel	NA	NA	NA
C	Location of Repeater Panel	NA	NA	NA
D	Alternate power Source	NA	NA	NA
E	Hooter's location	NA	NA	NA
<b>8</b>	<b>MOEFA</b>	NA	NA	NA
<b>9</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System</b>			
A	Basement	NA	NA	NA
B	Upper Floor	NA	NA	NA
C	Sprinklers above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal hydrants (Required only for A block)</b>			
A	Size of the riser/down comer	100 mm	100 mm	MR
B	No. Of hydrants per floor	01 no.	01 no.-A block 02 no.- office & library block	MR
C	Hose box	01 no.	01 no.-A block 02 no.- office & library block	MR
<b>12</b>	<b>Yard Hydrants</b>			
A	Total no. of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping arrangements</b>			
A	<b>Ground Level</b>			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pump	NA	NA	NA
d)	Discharge of jockey pump	NA	NA	NA
e)	Head of jockey pump	NA	NA	NA
f)	Discharge of Standby pump	NA	NA	NA
g)	Head of Standby pump	NA	NA	NA
h)	Auto starting/ manual stopping	NA	NA	NA
B	<b>Terrace Level</b>			
a)	Discharge of terrace pump	450 LPM	450 LPM	MR
b)	Head of terrace pump	40 m	40 m	MR
c)	Alternate power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive Water Storage for Fire Fighting</b>			
A	Underground tank capacity	NA	NA	NA
B	Draw off connection	NA	NA	NA
C	Fire Service Inlet	NA	NA	NA
E	Access to tank	NA	NA	NA
D	Overhead tank capacity	5,000 ltrs.	10,000 ltrs.	MR
<b>15</b>	<b>Exit Signage</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lift</b>			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Fireman switch	NA	NA	NA
E	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply</b>	NA	NA	NA

Ba 4/1

18	Refuge Area			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire Detection System panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any:			NA

As stated at N/14 a separate G+1 building was found constructed in the campus and school management has submitted an under taking that the same shall be used for the purpose of store. This building does not fall under the purview of Rule 27 of DFS Rules 2010.

The fire protection system provided in the school were tested, checked and random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety required as per rules FSC issued vide letter no. F6/DFS/MS/School/NDZ/2020/441 dated 22.10.2020, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Accordingly, DFA is put up for approval and signature please.

*Sumit Kumar*  
31/10/2023

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

~~DO (CD)~~  
~~31/10/23~~  
~~Dy. C.F.O. (CD)~~  
~~C.F.O.~~  
~~2/11/2023~~  
~~Director~~  
~~2/11/23~~  
~~ADOM SPM~~

F.T. letter is put up for signature, please.

~~Director (DFS)~~  
~~2/11/23~~  
*Sumit Kumar*  
06/11/2023