



No.F6/DFS/MS/School/NDZ/2023/ 782

Dated: 01/ 11 /2023

**FIRE SAFETY CERTIFICATE**

Certified that the Sardar Patel Modern School, Ghoroli Mayur Vihar-III, Delhi-110096, owned / occupied by Sardar Patel Modern School, comprised of Ground + 02 upper Floors, was issued Fire Safety Certificate vide letter No F6/DFS/MS/School/2019/NDZ/2338 dated 18.12.2019. The School building was re-inspected by the officer concerned of this department on 17/10/2023 in presence of Mrs. Shailee Bhandari (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the Fire Prevention and Fire Safety requirements in accordance with Circular No. 262-362 dated 17.01.2005 issued by Director of Education and that the building is fit for occupancy class "Educational" (Group-B) with effect from 01/ 11 /2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 01/11/2023 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

**Copy to:-**

1. Director of Education, Old Secretariat, Civil Lines, Delhi- 110054.
2. The Principal, Sardar Patel Modern School, Ghoroli Mayur Vihar-III, Delhi-110096.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas. occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

|      |  |  |                                   |                |
|------|--|--|-----------------------------------|----------------|
| 1    | Name & address of the building                             | Sardar Patel Modern School, Ghoroli Mayur Vihar-III, Delhi-110096. |                                   |                |
| 2    | Building is comprised of                                   | Ground + 02 upper floors.  |                                   |                |
| 3    | Type of occupancy  | Educational Building   |                                   |                |
| 4    | Type of case   | Renewal  |                                   |                |
| 5    | Details of previous FSC                                    | F6/DFS/MS/School/2019/NDZ/2338 dated 18.12.2019                    |                                   |                |
| 6    | Fire safety directives letter no.                          | Circular No. 262-362 dated-17/01/2005                              |                                   |                |
| 7    | Date of inspection   | 17.10.2023   |                                   |                |
| 8    | Name of the inspecting officers                            | Yashwant Singh Meena ADO (L.N)                                     |                                   |                |
| 9    | Name of the designation of officer from the building side  | Mrs. Shailee Bhandari (Principal)                                  |                                   |                |
| 10   | Year of construction                                       | 1993   |                                   |                |
| 11   | Applicant's letter no.                                     | Outdoor Diary No. 6988 Dated 05.10.2023                            |                                   |                |
| S.No | Minimum standard of fire prevention and fire safety U/R 33 | D.O.E. Cir. 262-362 dt.17.01.2005 Requirements                     | Provided at site                  | Remarks MR/NMR |
| 1    | <b>Access to Building:</b>                                 |  |                                   |                |
| A    | Road width   | 6.0 mtrs.  | 6.0 mtrs. ✓                       | MR             |
| B    | Gate width   | N/A  | N/A                               | N/A            |
| C    | Width of internal road                                     | N/A  | N/A                               | N/A            |
| 2    | <b>Number, Width, Type and Arrangement of Exits:</b>       |  |                                   |                |
| A    | <b>Number of staircases</b>                                |  |                                   |                |
| a    | Upper floor  | 02 nos.  | 02 nos. ✓                         | MR             |
| b    | Basement   | N/A  | N/A                               | N/A            |
| B    | <b>Width of staircases</b>                                 |  |                                   |                |
| a    | Upper floor  | 1.50 mtrs.   | 1.50 mtrs. & 1.36 to 1.40 mtrs. ✓ | MR             |
| b    | Basement   | N/A  | N/A                               | N/A            |
| C    | <b>Protection of exits</b>                                 |  |                                   |                |
| a    | Fire check door  | N/A  | N/A                               | N/A            |
| b    | Pressurization   | N/A  | N/A                               | N/A            |
| D    | No. of continuous staircases to terrace                    | 01 no.   | 01 no. ✓                          | MR             |
| E    | Width of corridor  | 1.50 mtr.  | 1.50 mtrs. ✓                      | MR             |
| F    | Door size  | 1.0 mtrs.  | 1.0 mtrs. ✓                       | MR             |
| 3    | <b>Compartmentation:</b>                                   |  |                                   |                |
| A    | Fire check door  | NA   | NA                                | NA             |
| B    | Sealing of electrical shafts                               | N/A  | N/A                               | N/A            |
| C    | Fire rating of shaft door                                  | N/A  | N/A                               | N/A            |
| D    | Water curtain  | N/A  | N/A                               | N/A            |
| E    | Fire dampers   | N/A  | N/A                               | N/A            |
| 4    | <b>Smoke Management System:</b>                            |  |                                   |                |
| A    | Basement   | N/A  | N/A                               | N/A            |
| B    | Upper floor  | N/A  | N/A                               | N/A            |

(W)

SO

| Fire Extinguisher:                              |                                |                       |                       |     |
|---|--------------------------------|-----------------------|-----------------------|-----|
| A   | Total numbers                  | 06 nos.               | 08 nos.               | MR  |
| B   | Types                          | CO <sub>2</sub> & ABC | CO <sub>2</sub> & ABC | MR  |
| C   | ISI marking                    | ISI Marked            | Provided              | MR  |
| 6 First-Aid-Hose Reel:                          |                                |                       |                       |     |
| A   | Total numbers of each floor    | 01 no.                | 01 no.                | MR  |
| B   | Length of hose reel hose       | 30 mtrs               | 30 mtrs               | MR  |
| C   | Nozzle diameter                | 5 mm                  | 5 mm                  | MR  |
| 7 Automatic Fire Detection and Alarming System: |                                |                       |                       |     |
| A   | Type of detectors              | N/A                   | N/A                   | N/A |
| B   | Location of main panel         | N/A                   | N/A                   | N/A |
| C   | Location of repeater panel     | N/A                   | N/A                   | N/A |
| D   | Alternate source of power      | N/A                   | N/A                   | N/A |
| E   | Hooters                        | N/A                   | N/A                   | N/A |
| 8   | MOEFA:                         | Required              | Provided              | MR  |
| 9   | Public Address System:         | N/A                   | N/A                   | N/A |
| 10 Automatic Sprinkler System:                  |                                |                       |                       |     |
| A   | Basement                       | N/A                   | N/A                   | N/A |
| B   | Upper floor                    | N/A                   | N/A                   | N/A |
| C   | Sprinkler above false ceiling  | N/A                   | N/A                   | N/A |
| 11 Internal Hydrants:                           |                                |                       |                       |     |
| A   | Size of riser/down-comer       | N/A                   | N/A                   | N/A |
| B   | Number of hydrants per floor   | N/A                   | N/A                   | N/A |
| C   | Hose box                       | N/A                   | N/A                   | N/A |
| 12 Yard Hydrants:                               |                                |                       |                       |     |
| A   | Total number of hydrants       | N/A                   | N/A                   | N/A |
| B   | Hose box                       | N/A                   | N/A                   | N/A |
| 13 Pumping Arrangements:                        |                                |                       |                       |     |
| 1 Ground level                                  |                                |                       |                       |     |
| A   | Discharge of main pump         | N/A                   | N/A                   | N/A |
| B   | Head of main pump              | N/A                   | N/A                   | N/A |
| C   | Number of main pumps           | N/A                   | N/A                   | N/A |
| D   | Jockey pump out put            | N/A                   | N/A                   | N/A |
| E   | Jockey pump head               | N/A                   | N/A                   | N/A |
| F   | Standby pump out put           | N/A                   | N/A                   | N/A |
| G   | Standby pump head              | N/A                   | N/A                   | N/A |
| H   | Auto starting /manual stopping | N/A                   | N/A                   | N/A |
| I   | Pump house access              | N/A                   | N/A                   | N/A |
| 2 Terrace Level                                 |                                |                       |                       |     |
| A   | Discharge of pump              | 450 LPM               | 450 LPM               | MR  |
| B   | Head of the pump               | 40 mtrs               | 40 mtrs               | MR  |
| C   | Power supply                   | Required              | Provided              | MR  |
| D   | Auto starting of pump          | Required              | Provided              | MR  |

|  |                              |             |             |     |
|--|------------------------------|-------------|-------------|-----|
| <b>14 Captive Water Storage for Fire Fighting:</b>                                 |                              |             |             |     |
| A  | Underground tank capacity    | N/A         | N/A         | N/A |
| B  | Draw-off connection          | N/A         | N/A         | N/A |
| C  | Fire service inlet           | N/A         | N/A         | N/A |
| D  | Access to tank               | N/A         | N/A         | N/A |
| E  | Overhead tank capacity       | 5,000 ltrs. | 5,000 ltrs. | MR  |
| <b>15 Exit Signage:</b>  |                              | Required    | Provided    | MR  |
| <b>16 Provision of Lifts:</b>  |                              |             |             |     |
| A  | Pressurization of lift shaft | N/A         | N/A         | N/A |
| B  | Pressurization of lift lobby | N/A         | N/A         | N/A |
| C  | Communication in lift car    | N/A         | N/A         | N/A |
| D  | Firemen's grounding switch   | N/A         | N/A         | N/A |
| E  | Lift signage                 | N/A         | N/A         | N/A |
| <b>17 Standby Power Supply:</b>  |                              | N/A         | N/A         | N/A |
| <b>18 Refuge Area:</b>   |                              |             |             |     |
| A  | Total area                   | N/A         | N/A         | N/A |
| B  | Location                     | N/A         | N/A         | N/A |
| <b>19 Fire Control Room:</b>   |                              |             |             |     |
| A  | Detector system panel        | N/A         | N/A         | N/A |
| B  | Flow switch panel            | N/A         | N/A         | N/A |
| C  | PA system panel              | N/A         | N/A         | N/A |
| D  | Battery backup               | N/A         | N/A         | N/A |
| E  | Building floor plans         | N/A         | N/A         | N/A |
| <b>20 Special Fire Protection systems for protection of special Risks, if any:</b> |                              | N/A         | N/A         | N/A |

The fire protection system was randomly tested, checked and was found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2023/413 dated 20.09.2023 by this department have been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 37 of Delhi Fire Service Rules 2010.



25/10/2023

Signature of the Inspecting Officer  
Name Yashwant Singh Meena  
Designation ADO (L.N)

DY.CFO (NDZ)

C.F.O.

Director

24/10/23

27/10/2023

31/10/23

ADO/LN