



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Audi/2023/SZ/ 369

Dated: 02/08/2023

FIRE SAFETY CERTIFICATE

Certified that the Auditorium Building at India Islamic Cultural Centre at 87- 88, Lodhi Road, New Delhi-110003, comprised of Lower Ground, Ground plus one Floor but Auditorium at first floor only, owned and occupied by India Islamic Cultural Centre, has already been issued fire safety certificate vide letter No. F6/DFS/MS/Audi/2020/SZ/263 dated 17.07.2020. The premises was re-inspected by the officer concerned of this department on dated 20.07.2023 in the presence of Mr. Mohd Nausherawan (Manager) and found that said premises have deemed complied with the fire prevention and fire safety in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for occupancy Class Group "D" Assembly (Auditorium) as above with effect from 02/08/2023 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/08/2023 at New Delhi.


(ATUL GARG)
DIRECTOR
Delhi Fire Service
6/6

Copy to:-

1. Sh. Mohd Nausherawan (Manager), India Islamic Cultural Centre 87-88, Lodhi Estate, New Delhi-110003.
2. The Additional Commissioner of Police (Lic.), 1st floor, PS Defence Colony, New Delhi-49.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: M/s Auditorium Building at India Islamic Cultural Centre, 87-88, Lodhi Estate, New Delhi-110003.
2. Building is comprised of : Lower ground, ground + one upper floor(Auditorium at first floor only having 300 seats)
3. Type of Occupancy : Group "D" Assembly Building
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/Audi/2020/SZ/263 dated 17.07.2020
6. Fire Safety directives Letter No. : F6/DFS/MS/95/4336 dated 10/04/1995
7. Date of inspection : 20/07/2023
8. Name of the Inspecting Officer : A.D.O. (S.J.) Santosh Kumar
9. Name and designation of Officer from the building side : Mr. Mohd Nausherawan(Manager)
10. Year of Construction : 2006
11. Applicant's letter No. : Outdoor dairy no 3820 dated 17/07/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	Old Noc Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	20 m	MR
	• Gate width	5m	5m	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	05 Nos.	05 Nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	Required	3nos.=1.5m, 1no=2m & 1no=1.25m	MR (old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	One	One	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	Required	03 Entry/Exits 2nos=1.5m & 1no=0.96m	MR (old case)
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 ACPH	NA	NA
	• Upper floors	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers			
	• Total numbers	06 nos.	10 Nos.	M/R
	• Types	ABC/W.Co2/CO ₂	ABC/W.Co2/CO ₂	M/R
	• ISI marking	Required	Provided	M/R

6.	First – Aid Hose Reels	Firefighting system is common for entire complex		
	• Total numbers on each floor	02 Nos. near Audi	4nos near Audi	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector CO	Smoke	Smoke	MR
	• Location of Main Panel	Ground Floor	Ground Floor	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Battery backup	MR
	• Hooters' Location	All Floor	All Floor	MR
	MOEFA	Required	Provided	MR
8.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrant	Firefighting system is common for entire complex		
	• Size of riser/down-comer	100mm	100mm	MR
	• Number of hydrants per floor	01no near Audi	01no near Audi	MR (old case)
	• Hose Box	01no near Audi	04nos near Audi	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
3.	Pumping Arrangements			
	• Ground Level	Firefighting system is common for entire complex		
	• Discharge of main pump	2800 LPM	2800 LPM	MR
	➤ Head of main pump	70m	70m	MR
	➤ Number of main pumps	01 No	01 No	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	70m	70m	MR
	➤ Standby Pump out put	2800 LPM	2800 LPM	MR
	➤ Standby Pump Head	70m	70m	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for firefighting	Firefighting system is common for entire complex		
	• Underground tank capacity	1,00,000 Ltr	1,00,000 Ltr	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 Ltr	30,000 Ltr	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room	Firefighting system is common for entire complex		
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	ABC & Co2 fire extinguishers provided for electric panel		MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Audi/2020/SZ/263 dated 17.07.2020 renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

[Signature]
27/07/23
Signature of the Inspecting Officer
Name : Santosh Kumar
Designation : A.D.O. (S.J.)

DO (S.J.)

Marle

24/7/23 1. Is there any basement?
C/o *26/7/2022* 2. If Yes then clarify smoke management system (N/A than MR?)

Director

DO (S.J.)

ADP/SSJ

for correction. (provided) 1. human 27/07/23