

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No. F.6/DFS/MS/CNG/2023/SZ/ 535

Dated: 10/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that the CNG Dispensing Station at Janak Puri, District Centre, New Delhi-110058, comprised of ground floor only, owned/occupied by Indraprastha Gas Limited, was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/ CNG/2020/SZ/328 dated 21/08/2020. The premises was re-inspected by the officer concerned of this department on 31/10/2023 in the presence of Manager and found that CNG Dispensing Station have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (CNG Dispensing Station) is fit for occupancy class Group "J" Hazardous Building w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....10/11/2023.....at New Delhi.

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Vice-President (F&S),  
Indraprastha Gas Limited, IGL Bhawan, Plot No.-4,  
Community Centre, Sector-9, R.K.Puram, New Delhi-110022
2. The Joint C.P. (Lic.),  
Police Station, Defence Colony, New Delhi

**Following fire safety directives must be adhered to –**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : CNG Dispensing Station at Janak Puri, District Centre, New Delhi-58
2. Building comprised of : Ground floor only.
3. Type of Occupancy : Group "J" Hazardous
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/CNG/2020/SZ/328 dated 21/08/2020
6. Fire Safety directives letter No : F.5/(3A)/DFS/CNG/2001/277 dated 09.10.2001
7. Date of inspection : 31/10/2023
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers  
From the building side : Manager
10. Year of Construction : 2001
11. Applicant's letter No. : IGL/F&S/2023/15/82/2 dated 26/09/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	09 m NA NA	Provided Directly accessible from road NA	MR NA NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA NA	NA NA	NA NA
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	12 no.'s DCP & CO <sub>2</sub> ISI	Provided Provided Provided	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	NA NA NA	NA NA NA	NA NA NA
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>• Gas and flame detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	Required NA NA Required NA	Provided Office at GF NA Provided At station	MR NA NA MR NA



<b>Fire Control Room</b>		NA	NA	NA
<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	CO <sub>2</sub> flooding system in compressor DCP flooding system for roof mounted two cascades	Provided  Provided	MR  MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/CNG/2020/SZ/328 dated 21/08/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

**Note:** Sand buckets are provided in the premises & No smoking boards adequately displayed in English and Hindi.

Advance fire water mist cum foam trolley is provided.  
Two hand held explosive meters are also provided.

*R.K. Yadav*  
Signature of Inspecting Officer 27/11/2023

Name:- R.K. Yadav  
Designation:- Asstt. Divisional Officer

Divisional Officer (South-West)

*an*  
8/11/23

Cfo (\$2)

*an*  
8/11/2023

Director

*an*  
9/11/23

*an*