



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/EH/SZ/2023/328

Dated: 07/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that M/s Genre (Toasted and Roasted Restaurant Pvt. Ltd) situated at Shop No. 7, Ground, First & Second Floor, Defence Colony Market, New Delhi-110024, comprised of Basement (other property), Ground plus 02 upper floors and the Eating House running at ground, 1<sup>st</sup> Floor & 2<sup>nd</sup> Floor only, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/SZ/2016/1269 dated 11/08/2016 in the name of M/s Desi Vibes (A unit of Khyati & Tiara Hospitality). The premise was re-inspected by the officers concerned of this department on 23/10/2023 in the presence of Mr. Kunal Singh and found that the said eating house at Ground, First & Second Floor only have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class "Group-D Assembly Building" as above with effect from 07/11/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 07/11/2023 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Deputy Health Officer, Central Zone, Municipal Corporation of Delhi, Jal Vihar, Lajpat Nagar, New Delhi-110024 (w.r.t. MHA ID No. 2023101117071 dated 18/10/2023)
2. Sh. Kunal Singh M/s Genre (Toasted and Roasted Restaurant Pvt. Ltd) situated at Shop No. 7, Ground, First & Second Floor, Defence Colony Market, New Delhi-110024

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know correct method of operation of fire fighting system.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its

INSPECTION REPORT				
1	Name & Address of the Building	M/s Genre (Toasted and Roasted Restaurant Pvt. Ltd), Shop No. 7, Ground, First & Second Floor, Defence Colony Market, New Delhi-110024		
2	Type of Occupancy	Group-D, "Assembly" (Eating House) (Eating House at GF, FF & SF only)		
3	Building Comprised of	Basement, Ground + 2 upper Floor. (Basement is others property)		
4	Type of Case	Renewal with Name change		
5	Details of Previous NOC	F.6/DFS/MS/EH/SZ/2016/1269 dated 11/08/2016 in the name of M/s Desi Vibes (A unit of Khyati & Tiara Hospitality)		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	23/10/2023		
8	Name of the Inspecting Officers	DO (SD) Manoj Kumar Sharma ADO (SJ) Santosh Kumar		
9	Name & Designation of Officers from the building side	Mr. Kunal Singh		
10	Year of construction	Prior to 2006		
11	Applicant letter / MHA ID No.	No. 2023101117071 dated 18/10/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Existing Fire Protection System	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	9m	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	2 Nos	2 Nos	MR
	➤ Basement floor.	N/A	N/A	N/A
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.25m & 0.75m	1.5m & 1m	MR (old case)
	➤ Basement floor	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	2m & 1m	Provided	MR (old case)
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5	<b>Fire Extinguishers.</b>			
	• Total numbers	ISI marked	7 Nos	MR
	• Types		ABC & CO <sub>2</sub>	MR
	• ISI Marking		Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	Hose-reels	One	MR
	• Length of hose-reel hose.		30m	MR
	• Nozzle Diameter		5mm	MR

N-7

7	<b>Automatic fire detection &amp; alarming system.</b>			N/A
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	MR
8	<b>MOEFA</b>	Required	Provided	N/A
9	<b>Public Address System</b>	N/A	N/A	
10	<b>Automatic Sprinkler System</b>			N/A
	• Basement	N/A	N/A	N/A
	• Ground floor.	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	100 mm	100 mm	MR
	• Number of Hydrant per floor	One	One	MR
	• Hose box.	One	One	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40m	40m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	10,000 Ltrs	Provided	MR (old case)
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

82

~

19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.			N/A

Note: -

1. In the previous inspection report, the composition of building is mentioned as Basement, Ground, 1<sup>st</sup> Floor, 2<sup>nd</sup> Floor and 3<sup>rd</sup> Floor, also in FSC Basement & 3<sup>rd</sup> Floor is shown as others property. However, the building now comprises basement, ground & two upper floors only.
2. The 2<sup>nd</sup> Floor is used for kitchen purpose only and there is no seating arrangement on second floor. The applicant has submitted an undertaking in this regard (Enclosed at C-27).

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/EH/SZ/2016/1269 dated 11/08/2016 in the name of M/s Desi Vibes (A unit of Khyati & Tiara Hospitality), renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended in the name of M/s Genre (Toasted and Roasted Restaurant Pvt. Ltd).

Accordingly, DFA is put up for approval and signature please.

*msk*

Signature of the Inspecting Officer  
Name: Manoj Kumar Sharma  
Designation: DO (SD)

*Santosh Kumar*  
01.11.23

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

CFO (HQ)

*[Signature]*  
3/11/2023

Director *[Signature]*  
3/11/23

*[Signature]*  
04/11/23

ADO (SJ) *msk*  
6/11/23

Sir, FT letter is put up for your signature pl.

Director *[Signature]*  
06/11/23

*Santosh Kumar*  
06/11/23