

C 41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/2023/ 330

Dated : 08/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Havemore Restaurant** located at **11-12, Pandara Road Market, New Delhi** is comprised of **Ground floor only**, was earlier granted FSC by this department vide letter No.F6/DFS/MS/EH/2020/NDZ/179 dated 16/12/20. Now, the premises was re-inspected by the officers concerned of this department on 30/10/23 in the presence of **Mr. Vaibhav Bajaj (Owner)** and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D Restaurant running at Ground floor only**, and valid up to **31.03.2026** from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 08/11/2023 at New Delhi by.

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Addl. Commissioner of Police (Lic), 1st floor, PS Defence Colony, New Delhi Online ID no. 2023041806788 dated 21.10.23.
3. The Manager, Havemore Restaurant, 11-12, Pandara Road Market, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape/ corridor shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration shall strictly be prohibited.

11/21  
**INSPECTION REPORT**

1. Name & address of the building Havemore Restaurant at 11-12, Pandara Road Market, New Delhi
2. Type of occupancy:- Assembly Building Group-D  
Ground floor only
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/2020/NDZ/179 dated 16/12/20
5. Fire safety directives No.- N/A
6. Date of inspection:- 30/10/23
7. Name of the inspecting officer:- Sh. Rajinder Atwal DO(CC)  
Sh. Ravinder Singh , ADO (CC)
8. Name & designation of officer from the building side:- Mr. Vaibhav Bajaj (Owner )
9. Year of construction:- Old Heritage Bldg.
10. Applicant's letter No:- Online ID no. 2023041806788 dated 21.10.23.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	Required	12 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 exit	Provided	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	07 Nos.	07 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

N/28

<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>			
<b>9.</b>	<b>Public Address System</b>			
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
<b>15.</b>	<b>Exit Signage.</b>			
		Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A

n/29

	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/2020/NDZ/179 dated 16/12/20, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

*[Handwritten Signature]*

*[Handwritten Signature]*

Name :- Rajinder Atwal  
Designation :- DO (CD)

Name : Ravinder Singh  
Designation : ADO (CC)

*[Handwritten Signature]*  
Sd/- (102)

*[Handwritten Signature]*  
RVP  
02/11/23

C.F.O.

*[Handwritten Signature]*  
3/11/2023

Director

*[Large Handwritten Signature]*  
3/11/23

*[Handwritten Signature]*

swi  
As approved, put up for kind perusal and signature please.

*[Handwritten Signature]*  
Director  
7/11/23

*[Handwritten Signature]*  
08/11/23

*[Handwritten Signature]*  
11/11