

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2023/SZ/331

Dated..09/11/2023

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of **M/s Havemore Restaurant Saket** located at Shop No 12 and 12-A, Ground Floor, MGF Metropolitan Mall, Saket, New Delhi-110017 in the building comprised of 02 tiers Basement, Ground plus Seven upper Floors owned/occupied by Vaibhav Bajaj (Partner) was issued FSC by this department vide letter no F6/DFS/MS/2020/SZ/EH/198 dated 11/12/2020. The restaurant premise was re-inspected by the officers concerned of this department on 01/11/2023 in the presence of Mr. Amit (Manager) and found that the said restaurant premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy **Class- D "Assembly Building"** and **validity upto 31/03/2026** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/11/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer, MCD, Public Health Department, Green Park, Delhi- 110016
(Ref. MHA Portal ID 2023102217625 dated 22/10/2023)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

INSPECTION REPORT

1	Name & Address of the Building	M/s Havemore Restaurant Saket located at Shop No 12 and 12-A, Ground Floor, MGF Metropolitan Mall, Saket, New Delhi-110017.		
2	Type of Occupancy	Restaurant at Ground Floor only		
3	Building Comprised of	02 tiers Basement, Ground plus Seven upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2020/SZ/EH/198 dated 11/12/2020		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2005/2150 dated 14/10/2005		
7	Date of Inspection	01/11/2023		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Amit (Manager)		
10	Year of construction	2007		
11	Applicant letter No.	MHA Portal ID 2023102217625 dated 22/10/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.	FSC- F6/DFS/MS/2019/SZ/464 dated 04/10/2023 for MGF Metropolitan Mall, Saket New Delhi		
	<ul style="list-style-type: none">Road widthGate widthWidth of internal road	09 mtr 05 mtr 06 mtr	Provided* Provided* Provided*	MR MR MR
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none">Upper floorsBasement floor	02 Nos 02 Nos	Provided* Provided*	MR MR
	b. Width of Staircase	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none">Upper floorsBasement floor	1.50 mtr each 1.50 mtr each	Provided* Provided*	MR MR
	c. Protection of exits	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none">Fire check doorPressurization	Required Required	Provided* Provided*	MR MR
	d. No. of continuous staircase to terrace	Required	Provided*	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.50m each	1.50 mtr & 1.50 m	MR
3	Compartmentation.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none">Fire check door.Sealing of electrical shafts.Fire rating of shaft door.Water curtainFire dampers.	Required Required 2 hrs N/A N/A	Provided* Provided* Provided N/A N/A	MR MR MR N/A N/A
4.	Smoke Management system.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none">BasementUpper floors	Required Required	Provided* Provided*	MR MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none">Total numbersTypesISI Marking	8 Nos ISI marked	08 Nos. ABC-04, W.CO ₂ -04 Provided	MR MR MR
6.	First Aid Hose Reels.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none">Total numbers on each floor.Length of hose-reel hose.Nozzle Diameter	Hose Reel	01 in Restaurant 30m 5mm	MR MR MR
7	Automatic Fire Detection and Alarming system. Provided & Maintained by MGF Metropolitan			
	<ul style="list-style-type: none">Type of detectors	Required	Smoke & Heat	MR

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Provided*	MR
		N/A	N/A	N/A
		Required	Provided*	MR
		Required	Provided*	MR
8.	MOEFA	Required	Provided*	MR
9.	Public Address System	Required	Provided*	MR
10.	Automatic Sprinkler System	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Basement 	Required	Provided*	MR
	<ul style="list-style-type: none"> Upper floors 	Required	Provided*	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	Required	Provided*	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	Required	Provided*	MR
	<ul style="list-style-type: none"> Hose box. 	Required	Provided*	MR
12.	Yard Hydrants.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Total number of hydrants. 	Required	Provided*	MR
	<ul style="list-style-type: none"> 2. Hose box. 	Required	Provided*	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	4500 LPM	Provided*	MR
	<ul style="list-style-type: none"> ➤ Head of main pump. 	60 mtr	Provided*	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	Two	Provided*	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	180 LPM	Provided*	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	60 mtr	Provided*	MR
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	4500 LPM	Provided*	MR
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	60 mtr	Provided*	MR
	<ul style="list-style-type: none"> ➤ Auto Starting / Manual Stopping. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Access to pump house 	Required	Provided*	MR
	<ul style="list-style-type: none"> Terrace Level 	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Required	Provided*	MR
14.	Captive water storage for Fire Fighting.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Underground tank capacity. 	3,00,000 Ltrs	Provided*	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	Required	Provided*	MR
	<ul style="list-style-type: none"> ➤ Access to tank. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	50,000 Ltrs	Provided*	MR
15.	Exit Signage.	Required	Provided*	MR
16.	Provision of Lifts.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Communication in lift car. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Fireman's switch. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Lift signage. 	Required	Provided*	MR
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A
19.	Fire Control Room.	Provided & Maintained by MGF Metropolitan Mall,		
	<ul style="list-style-type: none"> Detector System Panel. 	Required	Provided*	MR
	<ul style="list-style-type: none"> Flow Switch Panel. 	Required	Provided*	MR
	<ul style="list-style-type: none"> PA system Panel. 	Required	Provided*	MR

20.	<ul style="list-style-type: none"> Battery backup Building floor plan 	Required	Provided*	MR
		Required	Provided*	MR
		Required	Provided*	MR

Special Fire Protection System for the Protection of special Risk, if any :

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/2020/SZ/EH/198 dated 11/12/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

Handwritten signature
3/11/2023

Handwritten signature
Director
07/11/23

Handwritten signature
Arya

As approved, F.T. letter is put up for
your signature //

Handwritten signature
1/11/23
06/11/23

Handwritten signature
Director
01/11/23
m

Handwritten signature
09/11/23

Handwritten signature