

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/School/2023/SZ/789

Dated: 07/11/2023

FIRE SAFETY CERTIFICATE

Certified that the **MCD Primary (CO ED) School, Hauz Khas Village**, New Delhi-110016, comprised of ground plus two upper floors owned/occupied by Municipal Corporation of Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2020/SZ/574 dated 21/12/2020. The said premise was re-inspected by officer concerned of this department on 31/10/2023 in presence of Mrs. Veenu Singal (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class **"Educational Building Group - B"** with effect from 07/11/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued 07/11/23 at New Delhi by


(Anil Garg)
Director
Delhi Fire Service

Copy to: -

1. The Principal, MCD Primary (CO ED) School, Hauz Khas Village, New Delhi-110016
2. The Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept unlocked and free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	M.C.D Primary (CO ED) School, Hauz Khas Village, New Delhi -110016		
2	Type of Occupancy	Educational, Building Group-B		
3	Building Comprised of	Ground plus two upper floor		
4	Type of Case	F6/DFS/MS/School/2020/SZ/574 dated 21/12/2020		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	DOE Circular dated 01/03/2011		
7	Date of Inspection	31/10/2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Veenu Singal (Principal)		
10	Year of construction	2011		
11	Applicant letter No.	Email Dated 28/09/2003		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular 2011	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6mtr	MR
	• Gate width	4.5 mtr	Direct Accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	One	Two	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50 m / 0.75 m	1.27 m & 1.19 mtr	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	One	MR
	e) Width of corridor	-NA-	-NA-	MR
	f) Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	08Nos	09 Nos	MR
	• Types	ABC / Co2	ABC Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	one	one	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mtr	5mtr	MR

N/118

7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	NA	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	100m	100m	MR
	• Number of Hydrant per floor	one	one	MR
	• Hose box.	one	one	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40mtr each	40mtr each	MR
	➤ Power supply.	Required	Required	MR
	➤ Auto starting of pump.	Required	Required	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	10,000 ltr	10,000 ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-

~

N/17

	<ul style="list-style-type: none"> • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	One ABC type FE found provided near electrical panel board	MR
<p>The fire protection system provided in the building were randomly checked and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2020/SZ/574 dated 21/12/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <p style="text-align: right;">Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP)</p>				

DO (South)

merst
01/11/23

epo Thughy
2/11/2023

Director [Signature]
01/11/23

[Signature]
01/11/23

As approved, f-1 lett a in putup for
your signature pl

[Signature]
06/11/23

Director [Signature]
01/11/23