



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2023/333

Dated: 09/11/2023

FIRE SAFETY CERTIFICATE

Certified that M/s MIC Drop (A Unit of Chop House Hospitality Pvt. Ltd) at M-4, Second Floor, South Extension Part-2, New Delhi in a building comprised of Basement, Stilt, Ground floor & 02 upper floors. The restaurant is running at Second Floor only was issued Fire Safety Certificate vide this department letter No. F6/DFS/MS/EH/2021/SZ/06 dated 04/01/2021. The premise was re-inspected by the officer concerned of this department on 01/11/2023 in the presence of Mr. Aashwin and observed that the said eating house at Second Floor only have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class "Group-D Assembly Building" as above with effect from 09/11/2023 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 09/11/2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Deputy Health Officer, Central Zone, Municipal Corporation of Delhi, Jal Vihar, Lajpat Nagar, New Delhi-110024 (w.r.t. MHA ID No. 2023101617336 dated 25/10/2023)
2. Sh. Rupanjal Bangia M/s MIC Drop (A Unit of Chop House Hospitality Pvt. Ltd) at M-4, Second Floor, South Extension Part-2, New Delhi-110049

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know correct method of operation of fire fighting system.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

Covered area of the restaurant is 300m² and as per NBC (Part-IV) the no. of occupants comes out to be Approx. 167 (300/1.8=166.66). Thus capacity of restaurant is 167 persons which is covered under DFS Act 2007, Rules 2010. Subsequently inspection of Eating House is carried out as per NBC (Part-IV).

1. Name & address of the building : **M/s MIC Drop (A Unit of Chop House Hospitality Pvt. Ltd), M-4, 2nd Floor, South Extension Part-2, New Delhi-110049**
2. Type of Occupancy : **Assembly Building, Group-D (Restaurant)**
3. Building comprised of : **Basement, Stilt, Ground & 2 upper floor)**
4. Type of Case : **Renewal (Eating House)**
5. Details of previous NOC : **F6/DFS/MS/EH/2021/SZ/06 dated 04/01/2021**
6. Fire Safety directives letter no. : **NBC (Part-IV)**
7. Date of inspection : **01/11/2023**
8. Name of the Inspecting Officers : **ADO (SJ) Santosh Kumar**
9. Name and designation of officers : **Sh. Aashwin**
From the building side : **2012**
10. Year of Construction : **MHA ID No. 2023101617336 dated 25/10/2023**
11. Applicant's Letter No

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12m	12m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50m (each)	1.50m (each)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1.5m	2m & 1.5m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	6	6	MR
	• Types	ABC/CO ₂	ABC & Co2	MR
	• IS marking	Required	Provided	MR
6.	First – Aid Hose Reel			
	• Total numbers on each floor	One	One	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5 mm	5 mm	MR

7.	Automatic fire detection and alarming system		
	• Type of detector	NA	NA
	• Location of Main Panel	NA	NA
	• Location of Repeater Panel	NA	NA
	• Alternate source of power	NA	NA
	• Hooter's location	NA	NA
8.	MOEFA	Required	Provided
9.	Public Address System	NA	NA
10.	Automatic Sprinkler System		
	• Ground Floor	NA	NA
	• Upper Floor	NA	NA
	• Sprinkler above false ceiling	NA	NA
11.	Internal Hydrants		
	• Size of riser/down- comer	100 mm	100 mm
	• Number of hydrants per floor	1	1
	• Hose Box	1	1
12.	Yard Hydrants		
	• Total number of hydrants	NA	NA
	• Hose Box	NA	NA
13.	Pumping Arrangements		
	• Ground Level		
	➤ Discharge of main pump	NA	NA
	➤ Head of main pump	NA	NA
	➤ Number of main pumps	NA	NA
	➤ Jockey pump out put	NA	NA
	➤ Jockey pump head	NA	NA
	➤ Standby Pump out put	NA	NA
	➤ Standby Pump Head	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA
	➤ Pump House Access	NA	NA
	• Terrace level		
	➤ Discharge of pump	450 LPM	1620 & 180LPM
	➤ Head of the pump	40 MTR	40 m
	➤ Power supply	Required	Provided
	➤ Auto starting of pump	Required	Provided
14.	Captive water Storage for fire fighting		
	• Underground tank capacity	NA	NA
	➤ Draw of connection	NA	NA
	➤ Fire service inlet	NA	NA
	➤ Access to tank	NA	NA
	• Overhead Tank capacity	Required	Provided
15.	Exit Signage	Required	Provided
16.	Provision of Lifts		
	➤ Pressurization of Lift Shaft	NA	NA
	➤ Pressurization of lift lobby	NA	NA
	➤ Communication in lift Car	NA	NA
	➤ Fireman's Grounding Switch	NA	NA
	➤ Lift Signage	NA	NA
17.	Standby power supply	Required	Provided
18.	Refuge Area		
	➤ Total area	NA	NA
	➤ Location	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The Fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/EH/2021/SZ/06 dated 04/01/2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Suman
02.11.23
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

mm
27.11.23

- cfs*
1. Where is plan or drawing of eatery house?
 2. Segregation of kitchen is required or not?
 3. Clarify.

Khush
3.11.2023

DO (Santosh)

mm
4/11

ADO (SJ)

Sir, ops a renewed case Drawing is placed
1 case: Resubmitted for further order pl