



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Storage/SZ/2023/ 550

Dated: 15/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that M/s Air Cargo Logistic Centre 2B for Shristi Cargo Warehouse Pvt. Ltd, Opposite Gate No. 1, Near ATC Tower, IGI Airport, New Delhi-110037, comprised of ground plus one upper floor, owned/occupied by Delhi International Airport Limited was issued FSC by this department vide letter No. F.6/DFS/MS/Storage/2020/SZ/440 dated 02/11/2020. The premises was re-inspected by the officers concerned of this department on 06/11/2023 in the presence of Sh. Kailash Sharma and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/premises is fit for occupancy class "Group-H Storage Building" with effect from 15/11/2023 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 15/11/2023 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. Authorized Signatory, M/s Air Cargo Logistic Centre 2B for Shristi Cargo Warehouse Pvt. Ltd, Opposite Gate No. 1, Near ATC Tower, IGI Airport, New Delhi-110037
2. The Chief Executive Officer, DIAL, New Udaan Bhawan, Opposite T-3, IGI Airport, New Delhi-110037

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1.	Name & address of the building	M/s Air Cargo Logistic Centre 2B, Shristi Cargo Warehouse Pvt. Ltd., Opposite Gate No. 1, Near ATC Tower, IGI Airport, New Delhi-110037		
2.	Type of Occupancy	Storage Building (Group-H)		
3.	Building Comprised of	Ground + One upper floor (Small basement for pump house)		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/Storage/2020/SZ/440 dated 02.11.2020		
6.	Fire Safety directives/approval letter	F.6/DFS/MS/2020/BP/304 dated 21/08/2020 (C/19)		
7.	Date of inspection	06/11/2023		
8.	Name of Inspecting Officer	Manoj Kumar Sharma, DO (SD) Santosh Kumar, ADO (SJ)		
9.	Name and designation of Officer from building side	Sh. Kailash Sharma		
10.	Year of Construction	2020		
11.	Applicant letter No.	Outdoor Diary No. 8262 dated 03/11/2023		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Existing Fire Protection System	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	15m	MR
	• Gate width	6m	10m	MR
	• Width of internal road	6m	6m	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4 Nos	6 Nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.12m	1.5m (each)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width of Corridor	1.12m	1.5m	MR
	f. Door Size	0.81m	1.5m	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	60 Nos	60 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC type	MR
	• ISI marking	Required	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	8 Nos	10 Nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detector</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required	Beam & Multi Criteria	MR
		Ground floor	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		All Areas	Provided	MR
8.	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Ground &amp; Upper Floors</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150mm	Provided	MR
		8 Nos	Provided	MR
		8 Nos	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	12 Nos	Provided	MR
		12 Nos	Provided	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul> </li> </ul>	2850 LPM (Hyd) 4500 LPM (Spk)	2850 LPM (Hyd) 4500 LPM (Spk)	MR
		100m	100m	MR
		02 Nos	02 Nos	MR
		180 & 450 LPM	Provided	MR
		100m	Provided	MR
		4500 LPM	Provided	MR
		100m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		900 LPM	900 LPM	MR
		35m	35m	MR
		Required	Provided	MR
		Required	Provided	MR
14		Captive water Storage for fire fighting		
	<ul style="list-style-type: none"> <li>Underground tank capacity                             <ul style="list-style-type: none"> <li>Draw of connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	2,50,000 Ltrs	2 x 1,25,000 Ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Ltrs	20,000 Ltrs	MR
	Required	Provided	MR	
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	NA	NA	NA
		NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection system provided in the building were checked, tested at random and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F6/DFS/MS/Storage/SZ/2023/4074 dated 25/10/2023 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/Storage/2020/SZ/440 dated 02/11/2020, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Manoj Kumar Sharma*  
 Signature of the Inspecting Officer  
 Name: Manoj Kumar Sharma  
 Designation: DO (SD)

*Santosh Kumar*  
 06.11.23  
 Signature of the Inspecting Officer  
 Name: Santosh Kumar  
 Designation: ADO (S.J.)

CFO(HO)  
*Mugh*  
 7/11/2023  
Director  
*[Signature]*  
 8/11/23

*Asst. Secy*  
*[Signature]*  
 9/11/23

*04/SD* *Manoj*  
 10/11/23

Ans (15)

Sir, F.T letter is put up for your signature pl.

Director  
*[Signature]*  
*[Signature]*

*Santosh Kumar*  
 13.11.23