



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Storage/SZ/2023/ 549

Dated: 15/11/2023

FIRE SAFETY CERTIFICATE

Certified that M/s Delhi Cargo Service Center Pvt. Ltd, located at Cargo Terminal-2, Gate No. 6, IGI Airport, New Delhi-110037, comprised of Two interconnected buildings namely IA & IB each comprised of Ground, Mezzanine & one upper floor has already been issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/SZ/2021/29 dated 15/01/2021. The premises was re-inspected by the officers concerned of this department on 03/11/2023 in the presence of Sh. Deepak Karki & Sh. Surendra Yadav and found that the said building blocks have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/premises is fit for occupancy Class "Group-H Storage" as above with effect from 15/11/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 15/11/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Authorized Signatory, M/s Delhi Cargo Service Center Pvt. Ltd, at Cargo Terminal-2, Gate No. 6, IGI Airport, New Delhi-110037
2. Sh. Hrishekan, GM (Fire), New Udaan Bhawan, Near T-3, IGI Airport, New Delhi-37

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1.	Name & address of the building	Delhi Cargo Service Center Pvt. Ltd, at Cargo Terminal-2, Gate No. 6, IGI Airport, New Delhi-37		
2.	Type of Occupancy	Storage Building (Group-H)		
3.	Building Comprised of	IA: GF, Mezzanine Floor & 1 st Floor IB: GF, Mezzanine Floor (Partial) & 1 st Floor (Both IA & IB are interconnected)		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/SZ/2021/29 dated 15/01/2021		
6.	Fire Safety directives/approval letter	F6/DFS/MS/BP/2011/1585 dated 15/07/2011		
7.	Date of inspection	03/11/2023		
8.	Name of Inspecting Officer	DO (SD) M.K. Sharma ADO (SJ) Santosh Kumar		
9.	Name and designation of Officer from building side	Sh. Deepak Karki & Sh. Surendra Yadav		
10.	Year of Construction	2014		
11.	Applicant letter No.	Outdoor Diary No. 6753 dated 29/09/2023		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Existing Fire Protection System	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9m	Provided	MR
	• Gate width	5m	Provided	MR
	• Width of internal road	6m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	IA: GF to MF=3 Nos IA: MF to FF=3 Nos IB: GF to MF=2 Nos IB: MF to FF=3 Nos	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.12m	IA: GF to MF= 1.15, 0.97 & 1.15m IA: MF to FF= 1.32 & 1.15m x 2 IB: GF to MF= 1.50m & 1.48m IB: MF to FF= 1.50, 1.48 & 1.50m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	Provided	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Turbo Fans provided	MR
5.	Fire Extinguishers			
	• Total numbers		150 Nos	MR
	• Types	ISI marked	W.CO ₂ , DCP & CO ₂	MR
	• ISI marking		Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor		2 Nos	MR
	• Length of hose reel hose	Hose-reels	30m	MR
	• Nozzle diameter		5mm	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke & Heat	Smoke, Heat & Beam	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Required	FCC (T-3)	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	All Areas	MR
8.	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Ground & Upper Floors	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	150mm	Provided	MR
	• Number of hydrants per floor	2 Nos	Provided	MR
	• Hose Box	2 Nos	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	20 Nos	Provided	MR
	• Hose Box	20 Nos	Provided	MR
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	2850+4500 LPM	Provided	MR
	➤ Head of main pump	70m	Provided	MR
	➤ Number of main pumps	1 + 1	Provided	MR
	➤ Jockey pump out put	220 & 450 LPM	Provided	MR
	➤ Jockey pump head	70m (each)	Provided	MR
	➤ Standby Pump out put	4500 LPM	Provided	MR
	➤ Standby Pump Head	70m	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Underground tank capacity	7,00,000 Ltrs	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			MR	
	➤	Detector system panel	Required	Provided	MR
	➤	Flow Switch Panel	Required	Provided	MR
	➤	PA System Panel	Required	Provided	MR
	➤	Battery backup	Required	Provided	MR
➤	Building Floor Plans	Required	Provided	MR	
20.	Special Fire Protection Systems for Protection of special Risks, if any;		Required	Clean agent automatic flooding in HT & LT Panels	MR

The fire protection system provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/SZ/2021/29 dated 15/01/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

msk
 Signature of the Inspecting Officer
 Name: Manoj Kumar Sharma
 Designation: DO (SD)

Santosh Kumar
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (S.J.)

CFO (HO)
[Signature]
 Director
 8/11/2022

Pls Spk
DO/SD

FF PS

ADY SJ

msk
 13/11/22

Spoken
[Signature]
 13/11/23

ADO (SS)
 Sir, F.T letter is put up for your signature pl.
 Director
 13/11/23
[Signature]
 13.11.23