



C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2023 / School / WZ / 821

Dated: 16/11/2023

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Sarvodaya Co-ed Vidyalaya (ID No. 1411035)** located at **Wazirpur Village, Delhi- 52** comprised of **Ground and Three upper floors** owned/occupied by **Govt. Sarvodaya Co-ed Vidyalaya** was issued FSC by this department vide letter No **F-6/DFS/MS/WZ/2020/446** dated 26.10.2020. The building was inspected by the officer concerned of this department on 30.10.2023 in the presence of Smt. Parveen (In-charge), and observed that all the fire prevention and fire safety arrangements as provided in the building found in good working condition. The premises have deemed complied with the requirements in accordance with DOE Circular No. 3298-3398 dated 01/03/2011 and that the building/ premise is fit for occupancy **Group B Educational** with effect from16.11.2023 for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..16.11.2023.. at New Delhi, by


(Atul Garg)
Director
Delhi Fire Service


Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat ,Delhi-54.
2. The Principal, Govt. Sarvodaya Co-ed Vidyalaya, Wazirpur Village, Delhi-52.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on

WWW.dfs.Delhigovt.nic.in

N-13

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Co-ed Vidyalaya (School ID- 1411035) located at Wazirpur Village, Delhi-110052
2. Type of Occupancy : Educational
3. Building Comprised : Ground + Three Upper Floors
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/WZ/2020/446 Dated- 26/10/2020
6. Fire Safety directives letter No : DOE Circular No. 3298-3398 Dated 01/03/2011
7. Date of inspection : 30/10/2023
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers
From the building side : Smt. Parveen (In-charge)
10. Year of Construction : 2017
11. Applicant's letter No. : Form 'J' via outdoor diary no. 7151 , Dated-10/10/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5 m in each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.50 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	01@300 SQM	Provided	MR
	• Types	ABC/CO2	ABC/Co2	MR
	• IS marking	Yes	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA

N-14

Total Location

	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	NA	NA	NA
	<ul style="list-style-type: none"> • Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➢ Discharge of main Pump ➢ Head of Main pump ➢ Number of main pumps ➢ Jockey Pump out put ➢ Jockey pump head ➢ Standby Pump out put ➢ Standby Pump Head ➢ Auto Starting/Manual Stopping ➢ Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> • Discharge of pump • Head of the pump • Power Supply • Auto Starting of pump 	-	-	-
		450 lpm	Provided	MR
		40 m	40 m	MR
		Required	Provided	MR
		-	-	-
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➢ Draw-off connection ➢ Fire service inlet ➢ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			

✓

en

	Total Area	NA	NA	NA
	Location	NA	NA	NA
Fire Control Room				
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electric panel are not under the staircase.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures required under DOE Circular No. 3298-3398 dated 01/03/2011. It is recommended to renew the Fire Safety Certificate issued vide letter no. F6/DFS/MS/WZ/2020/446 dated 26/10/2020, under rule 35 of the Delhi Fire Service Rules 2010.

(Signature)
 ADO(B.W.)
 7/11/23

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

(Signature)
 Dy CPO (WZ)

(Signature)
 7/11

CPO
 8/11/2022
 Director

(Signature)
 9/11/23

(Signature)
 ADO/B.W.

For FT letter - refer to ssu plan

(Signature)
 ADO(B.W.)
 15/11/23

(Signature)
 Director (WZ)
 16/11/23

FOI 278
 dated 8/11/23