



C-35



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2023/ 819

Dated: 16/11/2023

FIRE SAFETY CERTIFICATE

Certified that the Nav Jeevan Model School located at WZ-III A/116, Vishnu Garden, New Delhi – 110018, comprised of Ground + 03 upper floors. Owned/occupied by Nav Jeevan Model School, The premises was inspected by the officer concerned by this department on 08/11/2023 in the presence of Ms. Sandeep Dixit (Manager) and found that the premises/building have complied with the fire prevention and fire safety requirements in accordance with the DOE Circular No. 262-362 dated 17/01/2005 and that the premises is fit for occupancy class "Educational" (Group B), with effect from ..16/11/2023.. for a period of three years in accordance with the Directorate of Education Circular No. 262-362 dated 17.09.2005, subject to the compliance of the conditions mentioned below.

Issued on ..16/11/2023.. at New Delhi.

(Atul Garg)
Director

Copy to: -

1. The Principal, Nav Jeevan Model School located at WZ-III A/116, Vishnu Garden, New Delhi – 110018.
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/16

INSPECTION REPORT

1. Name & address of the building : Nav Jeevan Model School located at WZ - IIIA/116, Vishnu Garden, New Delhi-110018.
2. Type of Occupancy : Educational (Ground + 3 Upper floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : DOE 262-362 dated 17/01/2005
6. Date of inspection : 08/11/2023
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Sh. Sandeep Dixit (Manager)
9. Year of Construction : 1989-90 (As per pre. insp. report dtd.- 13/01/2021)
10. Applicant's letter No. : Letter no. NJMS/VG/2023-24/949 dated 28/07/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE, circular 262-362 dated 17/01/2005	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.50 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts or less & 0.75 mt	1 mts & 0.90cms Provided	MR as approved at N-3
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	c. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1 m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

88

NITF				
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	220lpm & 180lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2,500 Ltrs	Provided	MR
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

	Standby power supply	NA	NA	NA
	Refuge Area.			
	> Total Area	NA	NA	NA
	> Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

NOTE :-

The school is running since 2008 as per record/correspondence with Delhi Fire Service at page no-C-05 to C-07. The inspecting officer of DFS has accepted the requirement of width of staircase is 1.0 mts as per DOE Circular no. 262-362 dated 17/01/2005 & the same is approved by this deptt. (Page no. - N/3) if agreed earlier all the shortcomings issued by this deptt. may be exempted.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. All the shortcomings issued by this department have been complied by the school management.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under DOE Circular no. DOE Circular No. 262-362 dated 17/01/2005 issued by Directorate of Education, Govt. OF NCT of Delhi is recommended.

29/ADOLMA
13/11/23

ADP (W12)

13/11/23

Signature of the Inspecting officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

ICFOI 80-10
Dated: 13.11.2023

13/11

14/11/2023

Director
14/11/23

M