

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/Educational/2023/SZ/ 30

Dated: 15/11/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Institute of Information Technology & Management (IITM), Plot No. D-29, Institutional Area, JanakPuri, New Delhi-110058, comprised of basement, ground plus six upper floors, owned/occupied by M/s Mata Leelawati Shikshan Sansthan (Regd.) was issued FSC vide letter No. F6/DFS/MS/2020/SZ/158 dated 18/03/2020 (For B,G+3 Floors). The building was re-inspected by the officers concerned of this department on 06/11/2023 in presence of Sh. Shiva Sharma and found that the building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi fire service Rules 2010 and that the building/premises is fit for occupancy class "Educational" w.e.f the date of issue of this certificate for a period of **three** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 15/11/2023 at New Delhi.

Atul Garg
15/11/23

(Atul Garg)
Director

Delhi Fire Service

HC

Copy to: -

1. Dy. Director, M/s Institute of Information Technology & Management (IITM), Plot No. D-29, Institutional Area, JanakPuri, New Delhi-110058.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Internal road of 06 m should be kept free from obstructions.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. Basement shall be used as per the building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

- 1. Name & address of the building : M/s Institute of Information Technology & Management (IITM), Plot No. D-29, Institutional Area, JanakPuri, New Delhi-110058.
- 2. Building comprised of : Basement, ground plus six upper floors
- 3. Type of Occupancy : Educational
- 4. Type of Case : Renewal/ addition/alteration
- 5. Details of Previous NOC : F6/DFS/MS/2020/SZ/158 dated 18/03/2020 (For B,G+3 Floors)
- 6. Fire Safety directives letter No : F6/DFS/MS/BP/2002/373 dated 04/03/2002(B, G+3) & F6/DFS/MS/BP/2018/339 dated 25/10/2018 (Added 4th 5th & 6th floor)
- 7. Date of inspection : 06/11/2023
- 8. Name of Inspecting Officer : A. D.O. R.K. Yadav & DO Vedpal Chhikara
- 9. Name and designation of officers
From the building side : Sh. Shiva Sharma
- 10. Year of Construction : 2002 & 2018
- 11. Applicant's letter No. : IITM/2K23/Acad/2116 dated 27/10/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06 m	13.7 m	M/R
	• Gate width	06 m	06 m	M/R
	• Width of internal road	06 m	06 m	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03 no.'s	Provided	M/R
	• Basements	2 Nos.	2 Nos.& ramp	N/A
	b. Width of staircases			
	• Upper Floor	1.50 m each	1.50 each	MR
	• Basement	1.50 m each	2x 1.50 m & ramp of 3.0 m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	M/R
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace			
		Two	Provided	M/R
	e. Width of Corridor	1.50 m	1.94 m	M/R
	f. Door Size	1.20 m	1.35 m Provided	M/R
3.	Compartmentation			
	• Fire check door	Required	Provided	M/R
	• Sealing of electrical shafts	Required	Provided	M/R
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	Required	Provided	M/R
4.	Smoke Management System			
	• Basements	Required	Provided	M/R
	• Upper floors	Required	Provided	M/R
5.	Fire Extinguishers			
	• Total numbers	04 no.'s each floors	Provided	M/R
	• Types	ABC/ CO ₂ type	Provided	M/R
	• IS marking	ISI marked	Provided	M/R

lc

h


First-Aid Hose Reels		03 no.'s	Provided	M/R
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 M	Provided	M/R
		05 MM	Provided	M/R
7.	Automatic fire detection and alarming system	N/A	N/A	N/A
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System	Required	Provided	M/R
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants	03 no.'s	Provided	M/R
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	3 Nos.	Provided	M/R
		3 Nos.	Provided	M/R
12.	Yard Hydrants	N/A	N/A	N/A
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	2280 LPM	2280 LPM	M/R
		70 m	70 m	M/R
		One	Provided	M/R
		180 LPM	Provided	M/R
		60 m	Provided	M/R
		2280 LPM	2280 LPM	M/R
		70 m	70 m	M/R
		Required	Provided	M/R
		Required	Provided	M/R
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	2,00,000 ltrs	2,00,000 Ltrs.	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		5,000 ltrs	10,000 Ltrs.	M/R
15.	Exit Signage.	Required	Provided	M/R


Provision of Lifts.				
	• Pressurization of Lift Shaft	Required	Provided	M/R
	• Pressurization of Lift lobby	Required	Provided	M/R
	• Communication In lift Car	Required	Provided	M/R
	• Fireman's Grounding Switch	Required	Provided	M/R
	• Lift Signage	Required	Provided	M/R
17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	Required	Provided	M/R
	• Battery backup	Required	Provided	M/R
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	HT & LT Panels provided	M/R



The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule 2010. Further the electric meter are installed away from staircases and exit route.

Note:- The Fire Safety Certificate was issued vide letter No. F6/DFS/MS/2020/SZ/158 dated 18/03/2020 as per guidelines issued vide No. F6/DFS/MS/BP/2002/373 dated 04/03/2002 (For B, G+3 upper Floors) & Now three more floors has been added (4th, 5th & 6th upper floors) & fresh guidelines issued vide letter No. F6/DFS/MS/BP/2018/339 dated 25/10/2018.


 Signature of Inspecting Officer
 Name:-R.K.Yadav
 Designation:-Asstt. Divisional Officer


 Signature of Inspecting Officer
 Name:- Vedpal Chhikara
 Designation:- DO(SW)

CFO (S2) 
 10/11/2023
 Director 
 19/11/23

DO/SW