

C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2023/School/WZ/ 825

Dated: 16/11/2023

FIRE SAFETY CERTIFICATE

Certified that the Naveen Public School, Village Nithari, Delhi-110086, comprised of Ground + 02 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/2017/School/WZ/2020/196 dated 19.06.2020. The premises was re-inspected by the officer concerned of this department on 01.11.2023 in the presence of Smt. Sunita (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from ...16/11/2023..... for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...16/11/2023 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Naveen Public School, Village Nithari, Delhi-110086.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules>
<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

INSPECTION REPORT

1. Name & address of the building		Naveen Public School, Village Nithari, Delhi-110086		
2. Type of Occupancy		Educational		
3. Type of Case		Renewal (Ground + 02 upper floors)		
4. Details of Previous NOC		F.6/DFS/MS/2017/School/WZ/2020/196 dated 19.06.2020		
5. Fire Safety directives letter No		NBC Part-IV		
6. Date of inspection		01.11.2023		
7. Name of Inspecting Officer		Sh. Ajay Kumar Sharma (ADO Rohini)		
8. Name and designation of officers From the building side		Smt. Sunita (Principal)		
9. Year of Construction		1996		
10. Applicant's letter No.		Online e-mail dated 26.10.2023.		
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			MR
	• Road width	Accessible	Accessible	MR(Old case)
	• Gate width	Accessible	4.0m	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	g. Number of staircases			MR
	• Upper Floors	04	04	-NA-
	• Basements	-NA-	-NA-	-NA-
	h. Width of staircases			MR(Old case)
	• Upper Floor	1.50m	2 x 1.50m, 3.9feet & 0.80mtr	-NA-
	• Basements	-NA-	-NA-	-NA-
	i. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	02	02	MR
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers			
	• Total numbers	15nos.	15nos.	MR
	• Types	ABC/CO2	ABC-9/CO2-6	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-

CW

	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	-NA-	-NA-	-NA-
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			

N/19

-NA-
-NA-

•	Detector System Panel	-NA-	-NA-	-NA-
•	Flow Switch Panel	-NA-	-NA-	-NA-
•	PA System Panel	-NA-	-NA-	-NA-
•	Battery backup	-NA-	-NA-	-NA-
•	Building Floor Plans	-NA-	-NA-	-NA-
10.	Special Fire Protection System for Protection of special Risks, if any:			

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 393 dated 12.09.2023, the FSC issued vide letter no. F.6/DFS/MS/2017/School/WZ/2020/196 dated 19.06.2020, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

[Handwritten Signature]

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

Dy. CFO(WZ)

[Handwritten Signature]
10/11/2023

~~2. 380 NW~~

~~10/11/23~~

[Handwritten Signature]

[Handwritten Signature]
13/11/2023

Director

[Large Handwritten Signature]
13/11/23

Ajay Kumar

Fi letter to put up for kind perusal and Signature please.

Director
[Handwritten Signature]
10/11/23
[Handwritten Signature]

[Handwritten Signature]
15/11/23