



FIRE SAFETY CERTIFICATE

Certified that the **Goldan Star Modern School**, located at **33 Feet Road, Gali No.8, E-Block, Nehru Vihar (Dayalpur), Delhi-110094**, now comprised of **Ground + 02 upper floors only** (Earlier it Ground + 01 upper floor only for which Fire Safety Certificate was issued by this department vide letter No. F6/DFS/MS/School/2019/NDZ/255 dated 01.02.2019), have complied with fire prevention & fire safety requirements in accordance with 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 26.10.2023 in presence of Mr. Pawan Kumar Sharma (Principal) and that the building /premises is fit for occupancy class **"Educational" (Group-B)** with effect from 20/11/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 20/11/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/11/2023

Copy to:-

1. Director of Education, B-Block, Yamuna Vihar, North-East, Delhi- 110053.
2. The Principal, Goldan Star Modern School, 33 Feet Road, Gali No. 8, E-Block, Nehru Vihar (Dayalpur), Delhi-110094.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Goldan Star Modern School, located at 33 Feet Road, Gali No.8, E-Block, Nehru Vihar (Dayalpur), Delhi-110094.		
2	Building is comprised of	Ground + 02 upper floors.		
3	Type of occupancy	Educational Building		
4	Type of case	New (Alteration of 2 nd floor on existing Ground + 01 upper floor)		
5	Details of previous FSC	F6/DFS/MS/School/2019/NDZ/255 dated 01.02.2019		
6	Fire safety directives letter no.	Circular No. 262-362 dated-17/01/2005		
7	Date of inspection	20.10.2023		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Pawan Kumar Sharma (Principal)		
10	Year of construction	2002		
11	Applicant's letter no.	Outdoor Diary No. 6488 Dated 22.09.2023		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirements	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 mtrs.	6.0 mtrs. ✓	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 nos.	02 nos. ✓	MR
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 mtrs.	1.46 mtrs. & 0.76mtr. ✓	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no.	01 no. ✓	MR
	E Width of corridor	1.50 mtr.	1.50 mtrs. ✓	MR
	F Door size	1.0 mtrs.	1.0 mtrs. ✓	MR
3	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

@

5. Fire Extinguisher:				
A	Total numbers	04 nos.	11 nos. ✓	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC ✓	MR
C	ISI marking	ISI Marked	Provided ✓	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	01 no.	01 no. ✓	MR
B	Length of hose reel hose	30 mtrs	30 mtrs ✓	MR
C	Nozzle diameter	5 mm	5 mm ✓	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump	450 LPM	450 LPM ✓	MR
B	Head of the pump	40 mtrs	40 mtrs ✓	MR
C	Power supply	Required	Provided ✓	MR
D	Auto starting of pump	Required	Provided ✓	MR

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 ltrs.	10,000 ltrs. ✓	MR
15 Exit Signage:				
		N/A	N/A	N/A
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17 Standby Power Supply:				
		N/A	N/A	N/A
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20 Special Fire Protection systems for protection of special Risks, if any:				
		N/A	N/A	N/A
		N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspections. Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular no. 262-362 Dated 17/01/2005, the PSC issued vide letter no. P/6/DI/S/MS/School/2019/NDZ/255 dated 01.02.2019 is recommended to be renewed.

Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (L.N)

BY C.F.O./NDZ

C.F.O.

10/11/23

13/11/2023

14/11/23