



C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/School/WZ/2023/ 822

Dated: 16/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Tagore Modern Public School**, Located at **Shalimar Bagh, New Delhi - 110088**, is running at Ground & 1<sup>st</sup> floor, in a building comprised of Basement + Ground + 02 Upper Floor, was issued FSC vide letter no. F.6/DFS/MS/WZ/2018/2565 dated 28/11/2018. The premises was re-inspected by the officer concerned of this department on 25/10/2023 in the presence of **Sh. Ravinder Singh Jain (Secretary)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Circular No. 262-362 dated 17/01/2005 and that the premises is fit for occupancy class "**Educational**" (**Group-B**) (For Ground and 1<sup>st</sup> floor only), with effect from ...16/11/2023...for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules,2010 condition mentioned below

Issued on ...16/11/2023...at New Delhi.

(Atul Gang)  
Director

**Copy to:**

1. The Principal, Tagore Modern Public School, Located at Shalimar Bagh, New Delhi - 110088.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

**Following fire safety directives must be adhered to:-**

1. **2<sup>nd</sup> floor shall not be used for any purpose.**
2. **Basement shall be used strictly as per BBL.**
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



2/7

### INSPECTION REPORT

1. Name & address of the building : Tagore Modern Public School located at Shalimar Bagh, New Delhi-110088.
  2. Type of Occupancy : Educational (Basement + Ground + 1 Upper floor)
  3. Type of Case : Renewal
  4. Details of previous NOC : F.6/DFS/MS/WZ/2018/2565 dated 28/11/2018
  5. Fire Safety directives letter No : DOE 262-362 dated 17/01/2005
  6. Date of inspection : 25/10/2023
  7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
  8. Name and designation of officers from the building side : Sh. Ravindra Singh Jain (Secretary)
  9. Year of Construction : 1991 (As per pre. insp. report dtd.- 09/10/2018)
  10. Applicant's letter No. : Letter dated nil, outdoor diary no. 4895 dated 14/08/2023
- \* The said school is running at Ground & 1<sup>st</sup> floor only in a building comprised of Basement + Ground + 02 upper floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE, circular 262-362 dated 17/01/2005	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	370cm Provided	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	2 Provided	MR
	• Basements	02	3 Provided	MR
	b. Width of staircases			
	• Upper Floors	1.5 mts	156cms (Including Railing), 70cm (Up to FF)	MR (old case)
	• Basements	1.5 mts	132cm, 150cm & 105cm	MR
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1 m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	08 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450lpm & 220lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltrs	Provided	MR
15	<b>Exit Signage.</b>	NA	NA	NA
16	<b>Provision of Lifts.</b>			

88X

4



MIR

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

\* Note: 1. 2<sup>nd</sup> floor shall not be used for any purpose.

2. Basement shall be used strictly as per BBL.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter no. F.6/DFS/MS/WZ/2018/2565 dated 28/11/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

File received Today (14/11/2023)  
*Dy c/o (10/2)*

*[Signature]*  
14/11/2023

*[Signature]*  
27/10/2023

Signature of the Inspecting officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

CFO/ S.S. Chakraborty  
dated 14/11/2023

*[Signature]*  
15/11/2023  
*[Signature]*  
14/11/23  
*[Signature]*