



e-34

75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2023/344

Dated: 21/11/2023

FIRE SAFETY CERTIFICATE

Certified that the Asur (A unit of Mashtun Hospitality LLP), located at 6A, Ground Floor, First floor, Second Floor & Third Floor, Shivaji Marg, Moti Nagar, New Delhi-110015, in a building comprised of Basement + Ground plus + 03 Upper Floors. Owned/Occupied by Asur (A unit of Mashtun Hospitality LLP), the building/premises was inspected by the officer concerned of this department on 15/11/2023 in the presence of Sh. Rohan Ratan Khare and found that the said premises/building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" (Group - D) and validity upto 31/03/2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions Printed Overleaf.

Issued on ..21/11/2023.. at New Delhi by.

(Atul Garg)
Director

21/11/2023

Copy to: -

1. The owner/occupier, Asur (A unit of Mashtun Hospitality LLP), located at 6A, Ground Floor, First floor, Second Floor & Third Floor, Shivaji Marg, Moti Nagar, New Delhi-110015. (Online Application ID No. 202310617309 dated 28/10/2023)
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (addlcp.lic-dl@nic.in.)
3. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhowest zone@gmail.com)
4. The Executive Engineer (Building), MCD, Vishal Enclave, Rajouri garden, New Delhi-110027.

INSPECTION REPORT

1. Name & address of the building	Asur (A unit of Mashtun Hospitality LLP), 6A, Ground Floor, First floor, Second Floor & Third Floor, Shivaji Marg, Moti Nagar, New Delhi-110015.
2. Type of Occupancy	Eating House /Assembly Occupancy
3. Type of Case	New
4. Details of previous NOC	Nil
5. Fire Safety directives letter No	Nil
6. Date of inspection	15/11/2023
7. Name of the Inspecting Officers	Sarabjeet Singh (ADO MN)
8. Name and designation of officers from the building side	Sh. Rohan Ratan Khare (Owner)
9. Year of Construction	2010
10. Applicant's letter No.	Online application ID No- 202310617309 dated 28/10/2023

The said restaurant is running at ground plus three upper floors in a building comprised of basement, ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 mts	Provided	MR
	• Gate width	4.5 mts	On main road	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	2mts & 1.5 mts	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2 X 1.5m	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	15	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2280 LPM	Provided	MR
	➤ Head of Main pump	70 MH	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70 MH	Provided	MR
	➤ Standby Pump out put	2280lpm	Provided	MR
	➤ Standby Pump Head	70 MH	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,00,000 ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

Provision of Lifts.

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
17/11/2023

[Signature]
17/11/2023
Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

[Signature]
17/11/2023

3/ADO/MN
7/11/2023

[Signature]
20/11/2023

Ol... 62
Dated... 17/11/2023

[Signature]
29/11/23

AND/MAN FT PS

Sir, F.T is put up for your kind personal & signature please.

[Signature]
20/11/2023