



FIRE SAFETY CERTIFICATE

Certified that the M/s Divya Jyoti Public School located at C-2B, Phase-II, Shiv Vihar, Main 33 Foota Road, Delhi-110031 building comprised of ground plus one upper floor, owned / occupied by Divya Jyoti Public School, was issued Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2018/NDZ/2648 dated 10/12/2018. The School building was re-inspected by the officer concerned of this department on 02/11/2023 in presence of Mr. Amit Sharma (Manager) In-Charge, and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the Fire Prevention and Fire Safety requirements in accordance with Circular No. 262-263 dated 17/01/2005 issued by Director of Education and that the School building is fit for occupancy class "Educational" (Group-B) with effect from 21/11/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to the conditions printed below.

Issued on 21/11/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
o/c @

Copy to:-

1. The Principal
M/s Divya Jyoti Public School, C-2B, Ph-II, Shiv Vihar, Delhi-31
2. The Dy. Director of Education
B-Block, Yamuna Vihar, Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N19

INSPECTION REPORT

1	Name & address of the building	Divya Jyoti Public School C-2B, Phase-II, Shiv Vihar, Main 33 Foota Road, Delhi-110094		
2	Building is comprised of	Ground plus first floor only		
3	Type of occupancy	Educational		
4	Type of case	Renewal		
5	Details of previous FSC	F.6/DFS/MS/School/2018/NDZ/2648 Dated 10/12/2018		
6	Fire safety directives letter no.	Circular 2005 issued by DoE		
7	Date of inspection	02/11/2023		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Amit Sharma (Manager)		
10	Year of construction	1994 & 1998		
11	Applicant's letter no.	Nil on dated 18/10/2023		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	10 mtrs.	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	01 nos.	02 nos.	MR
c	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 mtrs.	1.08 mtrs & 0.94 metre	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 nos.	01 nos.	MR
E	Width of corridor	1.50 mtrs.	1.08 mtr. (old accepted)	MR
F	Door size	1.0 mtrs.	1.0 mtrs.	MR
3	Compartmentation:			
A	Fire check door	N/A	N/A	N/A
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

W

5. Fire Extinguisher: N/10					
	A	Total numbers	04 Nos.	04 Nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:					
	A	Total numbers of each floor	01 No	01 No	MR
	B	Length of hose reel hose	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	6.05 mm	6.05mm	MR
7 Automatic Fire Detection and Alarming System:					
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	Provided	N/A
10 Automatic Sprinkler System:					
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:			N/A	N/A
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:					
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	220 Lpm	220 Lpm	MR
	B	Head of the pump	40 mtr	40 mtr	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

(1)

50/

