



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No.F6/DFS/MS/EH/NDZ/2023/345

Dated: 21/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that the India Islamic Culture Centre located at 87-88, Lodhi Estate, New Delhi-110003 building comprises of Lower Ground + ground floor + 01 upper floors, Eating House at ground floor only owned/occupied by India Islamic Culture Centre, was granted FSC by this department vide letter No. F6/DFS/MS/EH/2021/SZ/33 dated 17/02/2021. The premises was inspected by the officer concerned of this department on 17/11/2023 in the presence of Mr. N.C. Misra and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Assembly Building" (Group D), Restaurant/Eating House at ground floor only with effect from 21/11/2023 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 21/11/2023--at New Delhi by.

  
(Anil Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Deputy Commissioner (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi.  
**Online application ID no. 2023102817824.**
2. The Manager,  
India Islamic Culture Centre,  
87-88, Lodhi Estate, New Delhi-110003.

**Condition for the validity of fire safety certificate**

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
- 9 Any flammable material for interior decoration is prohibited.

### INSPECTION REPORT

1	Name & address of the building	India Islamic Culture Centre at 87-88, Lodhi Estate, New Delhi-110003		
2	Type of Occupancy	Assembly Building (Restaurant) Lower Ground + Ground + 01 upper floors, Restaurant at ground floor only		
3	Type of Case	Renewal		
4	Details of previous FSC	F6/DFS/MS/EH/2021/SZ/33 dated 17/02/2021		
5	Fire Safety directives Letter No.	N/A		
6	Date of inspection	17.11.2023		
7	Name of the Inspecting Officer	Sh. Manoj Kumar Sharma (DO/SD)		
8	Name and Designation of Officer from the building side	Mr. N.C. Misra		
9	Year of Construction	2006		
10	Applicant's letter No./ Online Id No.	MHA Id. 2023102817824 dated 03/11/2023		
Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building</b>			
	1 Road Width	12 mtr.	18 mtr.	MR
	2 Gate Width	N/A	N/A	N/A
	3 Width of Internal Road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangements of exits</b>			
	<b>A Number of Staircase</b>			
	1 Upper Floors	N/A	N/A	N/A
	2 Basement	N/A	N/A	N/A
	<b>B Width of Staircase</b>			
	1 Upper Floors	N/A	N/A	N/A
	2 Basement	N/A	N/A	N/A
	<b>C Protection of Exits</b>			
	1 Fire Check door	N/A	N/A	N/A
	2 Pressurization	N/A	N/A	N/A
	D No. of Continuous S/C to terrace	01 nos.	02 nos.	MR
	E Width of Corridor	2.0 mtr.	2.0 mtr.	MR
	F Door Size	Required	4 x 1.0 mtr. 1 x 1.70 mtr. 1 x 1.30 mtr.	MR
3	<b>Compartmentation</b>			
	1 Fire check door	N/A	N/A	N/A
	2 Sealing of electrical shafts	N/A	N/A	N/A
	3 Fire rating of shaft door	N/A	N/A	N/A
	4 Water curtain	N/A	N/A	N/A
	5 Fire Dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management System</b>			
	1 Basements	N/A	N/A	N/A
	2 Upper floors	12 a/c per hour	Exhaust fan	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	1 Total Numbers	06 Nos.	10 Nos.	MR
	2 Types	ABC & CO2	ABC & CO2	MR
	3 ISI Marking	Required	Provided	MR
<b>6</b>	<b>First-Aid Hose Reel</b>			
	1 Total number 1 <sup>st</sup> floor	01 nos.	01 nos.	MR
	2 Length of hose reel hose	30 mtr.	30 mtr.	MR
	3 Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1 Type of detectors	Heat & Smoke	Heat & Smoke	MR
	2 Location of main panel	Reception	Gr. floor	MR
	3 Location of repeater panel	N/A	N/A	N/A
	4 Alternate source of power	N/A	N/A	N/A
	5 Hooter's Location	Required	Provided	MR
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System</b>			
	1 Basement	N/A	N/A	N/A
	2 Upper floors	N/A	N/A	N/A
	3 Sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	1 Size of riser/down-comer	100 mm	100 mm	MR
	2 Number of hydrants per floor	01 nos.	01 nos.	MR
	3 Hose box	01 nos.	01 nos.	MR
<b>12</b>	<b>Yard Hydrants</b>			
	1 Total number of hydrants	N/A	N/A	N/A
	2 Hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping Arrangement</b>	Fire fighting system is common for entire building		
	<b>A Ground level</b>			
	1 Discharge of main pump	2800 LPM	2800 LPM	MR
	2 Head of main pump	40 MH	70 MH	MR
	3 Number of main pump	1	1	MR
	4 Jockey pump out put	180 LPM	180 LPM	MR
	5 Jockey pump head	40 MH	40 MH	MR
	6 Stand by pump output	2800 LPM	2800 LPM	MR
	7 Stand by pump head	40 MH	70 MH	MR
	8 Auto starting/Manual stopping	Required	Provided	MR
	<b>B Terrace level</b>			
	1 Discharge of pump	N/A	N/A	N/A
	2 Head of pump	N/A	N/A	N/A
	3 Power supply	N/A	N/A	N/A
	4 Auto starting of pump	N/A	N/A	N/A
<b>14</b>	<b>Capacity of Water Storage for Fire Fighting</b>			
	1 Underground tank capacity	1,00,000 ltr.	1,00,000 ltr.	MR
	2 Draw-off connection	Required	Provided	MR
	3 Fire service inlet	N/A	Provided	MR
	4 Access to tank	N/A	N/A	N/A



17/46

Asstt. Commr. Fire Service Deptt. Delhi

	5 Over head tank capacity	30,000 ltr.	30,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	1 Pressurization of lift shaft	N/A	N/A	N/A
	2 Pressurization of lift lobby	N/A	N/A	N/A
	3 Communication in lift car	N/A	N/A	N/A
	4 Fireman's switch	N/A	N/A	N/A
	5 Lift signage	N/A	N/A	MR
17	Stand by Power Supply	Required	Provided	N/A
18	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	1 Detector system panel	N/A	N/A	N/A
	2 Flow switch panel	N/A	N/A	N/A
	3 PA system panel	N/A	N/A	N/A
	4 Battery backup	N/A	N/A	N/A
	5 Building floor plan	N/A	N/A	N/A
20	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection and the system is common with whole building.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/EH/2021/SZ/33 dated 17/02/2021, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended.

*M.K. Sharma*  
 Signature of the Inspection Officer  
 Name :- M.K. Sharma  
 Designation:- DO/SD

*CFO*, *M.K.S*  
 20/11/2023  
 Director  
 21/11/23  
*MSL*

Uploaded  
 21/11/23