

0139

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2023/ 838

Dated: 21/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Rajkiya Pratibha Vikas Vidyalaya, Raj Niwas Marg, Delhi-54, comprised of ground + two upper floors with one separate auditorium was granted Fire Safety Certificate by this department vide letter no.F.6/DFS/MS/School/2013/NDZ/972 dated 25.09.2013. The premises/ building was re-inspected by the officer concerned of this department on 18.11.2023 in the presence of Principal and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with circular no. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by Director of Education and the premises/ building is fit for occupancy class (Group-B) "Educational Building" with effect from .....21/11/2023.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on .....21/11/2023.....at New Delhi by

  
(Arul Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
21/11

**Copy to:-**

1. The Principal, Rajkiya Pratibha Vikas Vidyalaya, Raj Niwas Marg, Delhi-54.
2. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.

**Condition for the validity of fire safety certificate:-**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : **Rajkiya Pratibha Vikas Vidyalaya, Raj Niwas Marg, Delhi-54**
2. Building is comprised of : **Ground + 02 upper floor**
3. Type of Occupancy : **Educational**
4. Type of Case : **Renewal**
5. Details of Previous FSC : **F.6/DFS/MS/School/2013/NDZ/972 dated 25.09.2013**
6. Fire Safety direction letter No : **F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11**
7. Date of Inspection : **18.11.2023**
8. Name of the Inspecting Officers: : **Sumit Kumar, ADO (SPM)**
9. Name of the designation of Officer from the building side : **Mr. Pundrikakshya Kaudinya (Principal)**
10. Year of Construction : **1954**
11. Applicant's letter No : **RPVV/RNM/2023/761 dated 17.11.2023**

S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated. 01.03.11	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2no.	3 no.	MR ✓
	Basement	NA	NA	NA
	B. Width of Staircases			
	Upper Floor	1.5 m	1.5 m each	MR ✓
	Basement	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	1no.	1 no.	MR ✓
	g. Width of Corridor	NA	NA	NA
	h. Door Size			
		1 m	1 m	MR ✓
3	Compartmentation			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire rating of shaft door	NA	NA	NA
	Water curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	Basement	NA	NA	NA
	Upper floor	NA	NA	NA

5.	Fire Extinguisher			
	Total numbers types IS marking	26 no.	38 no.	MR
		CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
		Required	Provided	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor  Length of hose reel hose Nozzle diameter	01 no.	03 no.	MR
		30 m	30 m	MR
		5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	NA	NA
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters's location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public address System.	NA	Provided	NA
10	Automatic Sprinkler System.			
	basement	NA	NA	NA
	upper floor	NA	NA	NA
	sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	size of riser/down-comer	NA	100 mm	NA
	Number of hydrants per floor	NA	03 no.	NA
	Hose Box	NA	03 no.	NA
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
		40 m	40 m	MR
	Head of the Pump	Required	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump			

- N/14-

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	10,000 Liters	20,000 Liters	MR ✓
15	Exit Signage.	Required	Provided	MR ✓
16	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	NA	NA	NA
	Firemen's grounding switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	Total area	NA	NA	NA
	Location	NA	NA	NA
19	Fire Control Room			
	Detector system panel	NA	NA	NA
	Flow switch panel	NA	NA	NA
	PA system panel	NA	NA	NA
	Batter backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the school were tested, checked at random found functional at the time of inspection.

Shortcomings communicated vide letter No.F6/DFS/MS/2019/School/7860 dated 24.12.2019 has been rectified.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required as per Director of Education Circular dated 01.03.2011, FSC issued vide letter in. F6/DFS/MS/school/2013/NDZ/972 dated 25.09.2013, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

*Sumit Kumar*  
29/11/2023

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

DO (CD) - on leave.

*DCPO (NDZ)*

*29/11/23*

*C.F.O.*

*26/11/2023*  
*Director*  
*29/11/23*