

c/42

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F-6/DFS/MS/SZ/2023/ EH/346

Dated: 23/11/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Barbeque Nation (A unit of Barbeque Nation Hospitality Ltd.) Located at, R-05, 5th floor, Vegas Mall, Plot No-6 Sector-14, North, Dwarka New Delhi-110078, in a building comprised of 4 Basement + Ground + 05 Upper Floors was issued FSC vide letter No. F6/DFS/MS/EH/2020/SZ/148, dated 02/11/2020. (Issued to Mall F6/DFS/MS/SZ/2022/62 Dated 09/12/2022) The premises was re - inspected by the officer concerned of this department on 16/11/2023 in the presence of Sh. Arvind Verma (Manager) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" Group D (5th Floor) and valid up to 31/03/2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on ... 23/11/2023 ... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
o/c

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, New Delhi.
2. The Manager, M/s Barbeque Nation (A unit of Barbeque Nation Hospitality Ltd.) Located at, R-05, 5th floor, Vegas Mall, Plot No-6 Sector-14, North, Dwarka New Delhi-110078.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/9

INSPECTION REPORT

1. Name & address of the building: M/s Barbeque Nation (A unit of Barbeque Nation Hospitality Ltd.) Locatrd at, R-05, 5th floor, Vegas Mall, Plot No-6 Sector-14, North, Dwarka New Delhi-110078.
2. Type of Occupancy : Class-D (Assembly) (At Fifth Floor in the Mall)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2020/SZ/148, dated 02/11/2020
(Issued to Mall F6/DFS/MS/SZ/2022/62, dated 09/12/2022)
5. Fire Safety directives Letter No. :F6/DFS/MS/BP/2016/326 Dated
16/12/2016 (issued to mall)
6. Date of inspection : 16/11/2023
7. Name of the Inspecting Officer ; ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Arvind Verma (Manager)
9. Year of Construction : 2019
10. Applicant's letter No. :2023110381080, dated-03/11/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/5 & N/6	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12mtrs	Provided	MR
	• Gate width	06mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits (Common With Mall)			
	a. Number of staircases			
	• Upper floors	3	03 Provided (by Mall)	MR
	• Basements	NA	12 Provided by Mall	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided by Mall	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Same as vegas mall	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1.5m	Provided	MR
3.	Compartmentation(Common With Mall)			
	• Fire check door	NA	Provided by Mall	NA
	• Sealing of electrical shafts	NA	Provided by Mall	NA
	• Fire Rating of shaft door	NA	Provided by Mall	NA
	• Water Curtain	NA	Provided by Mall	NA
	• Fire Dampers	NA	Provided by Mall	NA

N/10

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided by Mall	MR
5.	Fire Extinguishers			
	• Total numbers	As per IS 2190/92	4 nos.	MR
	• Types	ABC, CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reel	Common with mall		
	• Total numbers on each floor	Required	Provided by Mall	MR
	• Length of hose reel hose	36 m	Provided by Mall	MR
	• Nozzle diameter	5 mm	Provided by Mall	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke/ Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided by Mall	MR
10.	Automatic Sprinkler System (Common with mall)			
	• Basements	NA	Provided	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants: (Common with the mall)			
	• Size of riser/down- comer	150 mm	Provided by Mall	MR
	• Number of hydrants per floor	1	3 Provided by Mall	MR
	• Hose Box	Required	Provided by Mall	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided by Mall	NA
	• Hose Box	NA	Provided by Mall	NA
13.	Pumping Arrangements: Common with Mall			
	• Ground Level			
	• Discharge of main pump	2850 lpm	Provided	MR
	➤ Head of main pump	120 m	Provided	MR
	➤ Number of main pumps	02	Provided	MR
	➤ Jockey pump out put	180 LPM 2 Nos+ Water Curtain Pump 2280 LPM	Provided	MR
	➤ Jockey pump head	120 m	Provided	MR
	➤ Standby Pump out put	2850 lpm	Provided	MR
	➤ Standby Pump Head	120 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

N/11

14.	Captive water Storage for fire fighting: Common with Mall			
	• Under ground tank capacity	400000 ltr	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts Common with Mall			
	➤ Pressurization of Lift Shaft	NA	Provided By Mall	NA
	➤ Pressurization of lift lobby	NA	Provided By Mall	NA
	➤ Communication in lift Car	NA	Provided By Mall	NA
	➤ Fireman's Grounding Switch	NA	Provided By Mall	NA
	➤ Lift Signage	NA	Provided By Mall	NA
17.	Standby power supply	Required	Provided By Mall	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room(Common with Mall)			
	➤ Detector system panel	NA	Provided By Mall	NA
	➤ Flow Switch Panel	NA	Provided By Mall	NA
	➤ PA System Panel	NA	Provided By Mall	NA
	➤ Battery backup	NA	Provided By Mall	NA
	➤ Building Floor Plans	NA	Provided By Mall	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2020/SZ/148, dated 02/11/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

UdaiVir Singh
 Signature of the Inspecting Officer
 Name UdaiVir Singh
 Designation ADO/DWK

UdaiVir Singh
 20/11/23

CFo(S2)
 20/11/2023

Director
 20/11/23