



**FIRE SAFETY CERTIFICATE**

Certified that G.D. Goenka School located at Arya Nagar, Jagrati CGHS, Behind Karkardoma Metro Station, Delhi-11092, comprised of basement, ground plus four upper floor, owned / occupied by G.D. Goenka School was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2020/NDZ/433 dated 19/10/2020. The School building was re-inspected by the officer concerned of this department on 13/11/2023 in presence of Mr. Sushil Kumar (Administrative Officer) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with the Fire Prevention and Fire Safety requirements in accordance with Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education and that the building is fit for occupancy class "Educational" (Group-B) with effect from 23/11/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 23/11/2023 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

**Copy to:-**

1. The Principal, G.D. Goenka School at Arya Nagar, Jagrati CGHS, Behind Karkardoma Metro Station, Delhi-11092
2. The Dy. Director of Education, D-Block, Anand Vihar, Delhi-110092.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

2/14

**INSPECTION REPORT**

1	Name & address of the building	G.D. Goenka School at Arya Nagar, Jagrati CGHS, Behind Karkardoma Metro Station, Delhi-11092
2	Building is comprised of	Basement, Ground + 04 Upper floors only (Two Rooms).
3	Type of occupancy	Educational Building
4	Type of case	Renewal ✓ ✓
5	Details of previous FSC	F6/DFS/MS/School/2020/NDZ/433 dated 19/10/2020
6	Fire safety directives letter no.	Delhi Fire Service Act.2007 And Rules 2010.
7	Date of inspection	13/11/2023
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
9	Name of the designation of officer from the building side	Mr. Sushil Kumar (Administrative Officer)
10	Year of construction	2011
11	Applicant's letter no.	Email dated 06/11/2023

S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
------	--	-------------	------------------	----------------

<b>1 Access to Building:</b>				
A	Road width	6.0 mtrs.	12 mtrs. ✓	MR
B	Gate width	4.5 mtrs.	6.0 mtrs. ✓	N/A
C	Width of internal road	N/A	N/A	N/A

<b>2 Number, Width, Type and Arrangement of Exits:</b>				
<b>A Number of staircases</b>				
a	Upper floor	02 nos.	02 nos. ✓	MR
c	Basement	02 nos.	02 nos. Ramp ✓	MR
<b>B Width of staircases</b>				
a	Upper floor	1.50 mtrs.	1.30 mtrs. to 1.50 mtrs each ✓	MR (old case) ⊕
b	Basement	1.50 mtrs.	1.30 mtrs. to 1.50 mtrs each. ✓	MR (old case) ⊕
<b>C Protection of exits</b>				
a	Fire check door	Required	Provided ✓	MR
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	02 no.	02 no. ✓	MR
E	Width of corridor	1.50 mtrs.	1.50 mtrs. ✓	MR
F	Door size	1.0 mtrs.	1.0 mtrs. ✓	MR

<b>3 Compartmentation:</b>				
A	Fire check door	Required	Provided ✓	MR
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A

<b>4 Smoke Management System:</b>				
A	Basement	Required	Provided ✓	MR
B	Upper floor	Required	Provided ✓	MR


Ⓢ

<b>5.</b>	<b>Fire Extinguisher:</b>			
A	Total numbers	15 Nos.	25 Nos. ✓	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC ✓	MR
C	ISI marking	ISI Marked	Provided ✓	MR
<b>6.</b>	<b>First-Aid-Hose Reel:</b>			
A	Total numbers of each floor	02 Nos.	02 Nos. ✓	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs. ✓	MR
C	Nozzle diameter	05 mm	05 mm ✓	MR
<b>7.</b>	<b>Automatic Fire Detection and Alarming System:</b>			
A	Type of detectors	N/A	Smoke ✓	MR
B	Location of main panel	N/A	At Reception ✓	MR
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	Provided ✓	MR
E	Hooters	Staircase	Staircase ✓	MR
<b>8.</b>	<b>MOEFA:</b>	Required	Provided ✓	MR
<b>9.</b>	<b>Public Address System:</b>	Required	Provided ✓	MR
<b>10.</b>	<b>Automatic Sprinkler System:</b>			
A	Basement	Required	Provided ✓	MR
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	Required	Provided ✓	MR
<b>11.</b>	<b>Internal Hydrants:</b>			
A	Size of riser/down-comer	100 mm	100 mm ✓	MR
B	Number of hydrants per floor	01 no.	01 no. ✓	MR
C	Hose box	01 no.	01 no. ✓	MR
<b>12.</b>	<b>Yard Hydrants:</b>			
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangements:</b>			
<b>1</b>	<b>Ground level</b>			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	180 LPM	180 LPM ✓	MR
E	Jockey pump head	40 mtrs	40 mtrs ✓	MR
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2</b>	<b>Terrace Level</b>			
A	Discharge of pump	900 LPM	1200 LPM ✓	MR
B	Head of the pump	40 mtrs	56 mtrs ✓	MR
C	Power supply	Required	Provided ✓	MR
D	Auto starting of pump	Required	Provided ✓	MR

14	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	N/A	1,00,000 ltr. ✓	MR
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	Required	Provided ✓	MR
E	Overhead tank capacity	25,000 ltrs.	30,000 ltrs. ✓	MR
15	<b>Exit Signage:</b>	Required	Provided ✓	MR
16	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	Required	Provided ✓	MR
D	Firemen's grounding switch	Required	Provided ✓	MR
E	Lift signage	Required	Provided ✓	MR
17	<b>Standby Power Supply:</b>	Provided	Required ✓	MR
18	<b>Refuge Area:</b>			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	<b>Fire Control Room:</b>			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.


Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular no F16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011, the FSC issued vide letter no. F6/DFS/MS/School/2020/NDZ/433 dated 19/10/2020 is recommended to be renewed.

  
 Signature of the Inspecting Officer  
 Name Yashwant Singh Meena  
 Designation ADO (L.N)

Dy. CFO (NDZ)

  
 20/11/23

C.F.O.

  
 20/11/2023

Director

  
 20/11/23

H B