

No. F6/DFS/MS/School/WZ/2023/ 841

Dated:- 23/11/2023

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidyalaya (New Building) Located at Tikri Kalan, New Delhi-110041, comprised of Two Blocks of Ground + 03 Upper Floors only owned/occupied by Govt. Sarvodaya Kany Vidyalaya, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2020/326 dated 04/09/2020. The said premise was re-inspected by the officer concerned of this department on 08/11/2023 in the presence of Ms. Sangita (Principal) & Sh. Sandeep (Estate Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 3298-3398 dated 01/03/2011 / NBC (Part-IV) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 23/11/2023 for a period of three years, in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010, printed below:

Issued on 23/11/2023 at New Delhi by.

(Atul Gaig)
Director
Tel. No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Govt. Sarvodaya Kanya Vidyalaya (New Building), Tikri Kalan, New Delhi-110041.

3. Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **Govt. Sarvodaya Kanya Vidyalaya (New Building) located at Tikri Kalan, New Delhi-110041.**
2. Type of Occupancy : Educational, (02 Block - Ground+03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2020/326 dated 04/09/2020
5. Fire Safety directives Letter No. : Cr. No. 3298-3398 dated 01/03/2011 / NBC (Part-IV)
6. Date of inspection : 08.11.2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Ms. Sangita (Principal) & Sh. Sandeep (Estate Manager)
9. Year of Construction : 2016-17
10. Applicant's letter No. : email dated 07.11.2023

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cr. No. 3298-3398 dated 01/03/2011/NBC (Part-IV) Requirements/as per FSC dated 04.09.2020	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 in each block	02 in each block	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	1.8 m x 2 (I-Block) 1.8 m x 2 (L-Block)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	01	Provided	MR
	d. No of continuous staircase to terrace			
	• Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	1 m x 2	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

N-20					
5.	Fire Extinguishers				
	• Total numbers	12 nos. in each block	15 nos.		MR
	• Types	ABC & CO ₂	Provided		MR
	• IS marking	ISI marked	Provided		MR
6.	First – Aid Hose Reels				
	• Total numbers on each floor	01	02		MR
	• Length of hose reel hose	30 m	Provided		MR
	• Nozzle diameter	5 mm	Provided		MR
7.	Automatic fire detection and alarming system				
	• Type of detectors	NA	NA		NA
	• Location of Main Panel	NA	NA		NA
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	NA	NA		NA
	• Hooters' Location	NA	NA		NA
8.	MOEFA	NA	NA		NA
9.	Public Address System	NA	NA		NA
10.	Automatic Sprinkler System				
	• Basements	NA	NA		NA
	• Upper Floor	NA	NA		NA
	• Sprinkler above false ceiling	NA	NA		NA
11.	Internal Hydrants:				
	• Size of riser/down- comer	NA	NA		NA
	• Number of hydrants per floor	NA	NA		NA
	• Hose Box	NA	NA		NA
12.	Yard Hydrants				
	• Total number of hydrants	NA	NA		NA
	• Hose Box	NA	NA		NA
13.	Pumping Arrangements:				
	• Ground Level				
	• Discharge of main pump	NA	NA		NA
	➤ Head of main pump	NA	NA		NA
	➤ Number of main pumps	NA	NA		NA
	➤ Jockey pump out put	NA	NA		NA
	➤ Jockey pump head	NA	NA		NA
	➤ Standby Pump out put	NA	NA		NA
	➤ Standby Pump Head	NA	NA		NA
	➤ Auto Starting/Manual stopping	NA	NA		NA
	➤ Pump House Access	NA	NA		NA
	• Terrace level				
	➤ Discharge of pump	450 lpm in each block	450 lpm x 2 in each block		MR
	➤ Head of the pump	40 m	Provided		MR
	➤ Power supply	Required	Provided		MR
	➤ Auto starting of pump	Required	Provided		MR
14.	Captive water Storage for fire fighting:				
	• Under ground tank capacity	NA	NA		NA
	➤ Draw off connection	NA	NA		NA
	➤ Fire service inlet	NA	Provided		NA
	➤ Access to tank	NA	NA		NA
	• Overhead Tank capacity	10,000 ltrs. In each block	10,000 ltrs. In each block		MR
15.	Exit Signage	Required	Provided		MR
16.	Provision of Lifts				
	➤ Pressurization of Lift Shaft	NA	NA		NA
	➤ Pressurization of lift lobby	NA	NA		NA
	➤ Communication in lift Car	NA	NA		NA
	➤ Fireman's Grounding Switch	NA	NA		NA

	> Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	> Total area	NA	NA	NA
	> Location	NA	NA	NA
19.	Fire control room			
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2020/326 dated 04/09/2020 is recommended under rule 37 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

Accordingly DFA is put up for approval please.

[Signature]
09/11/23
Aman Kumar Lathar
ADO (JWP)

[Signature]
09/11/2023

[Signature]
09/11/2023

[Signature]
09/11/2023

[Signature]
10/11/2023

[Signature]
10/11/23

[Signature]

Sir, F.S. letter is put-up for your signature.

[Signature]
17/11/23

[Signature]
10/11/23
ADO (JWP)