



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

d48



No. F6/DFS/MS/2023/School/ 844

Dated: 23/11/2023

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidyalaya (School I'd No- 1207036) located at Burari, Delhi-110084 comprised of 03 blocks (01 Block comprised of ground + first floor & 02 block comprised of ground + 03 upper floors each) owned/ occupied by Govt. Sarvodaya Kanya Vidyalaya was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/2020/WZ/School/428 dated 15.10.2020. The premise was re-inspected by the officer concerned of this department on 06.11.2023 in the presence of Mrs. Monika, Principal and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under "Educational Group B" with effect from 23/11/2023 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 23/11/2023 at New Delhi


(Atul Garg)
Director
Ph:-011-23414000
ofc

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Govt. Sarvodaya Kanya Vidyalaya (School I'd No- 1207036) located at Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Kanya Vidhyalaya at Burari, Delhi-84. (School Ed No-1207036)
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : 03 blocks (01 block, Ground + first floor, 02 & 03 block Ground + 03 upper floors)
5. Details of previous NOC : F6/DFS/MS/2020/WZ/School/428 Dated. 15.10.2020
6. Fire Safety directives letter No : Nil
7. Date of inspection : 06.11.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mrs. Monika, Teacher
10. Year of Construction : 2017
11. Applicant's letter No. : Online e-mail dated: 25.10.2023

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Block-I-02 Block-II-03 Block-III-04	Block-I-02 Block-II-03 Block-III-05	MR
	• Upper Floors			
	• Basements			
	b. Width of staircases	1.50m	Block-I-(G+3)-02 nos. of 1.80m Block-II old (G+1)-1.50m x 02 & 1.10m iron staircase Block-III(G+3)-05 nos. of 1.70m	MR
	• Upper Floors			
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	NA	Provided	NA
	f. Door Size	1 m	1.10m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	50nos	80nos	MR
	• Types	ABC/Co2	ABC-40 Co2-40	MR
	• ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
			(02 New block G + 03)	

		N/25		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	03 each floor	Provided	MR
		30 m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA			
		NA	NA	NA
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	Provided	NA
		NA	Provided	NA
		NA	01	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements. (for New Block-II & II)			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm x2 each block	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting. (New Block-II & III)			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

64

	• Overhead Tank capacity	10,000ltr	Provided each block	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/School/451 dated 04.10.2023.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, the FSC issued vide letter of even no. F6/DFS/MS/2020/WZ/School/428 dated 15.10.2020 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation :- ADO/RN

Dy. Chief Fire Officer (WZ)

Please check the elect. meter & elect. panel below staircase & put up accordingly,

CGFO/372-NW ADD(RN)
Dated... 08/11/23

Sir,

As per your direction Re-visit at school building on dated 17-11-2023 and found that there is not install any electric meter & panel.
Resubmitted please.

Signature
17/11/24