



No.F6/DFS/MS/School/NDZ/2023/ 846

Dated: 23/11/2023

FIRE SAFETY CERTIFICATE

Certified that Govt. Sarvodaya Kanya Vidyalaya located at Krishna Nagar, Delhi 110051 building comprised of ground plus two upper floors only; owned / occupied by Govt. Sarvodaya Kanya Vidyalaya was issued Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2014/NDZ/1320 dated 21/10/14 (for ground plus one upper floor). The School building was re-inspected by the officer concerned of this department on 06/11/2023 in presence of Mr. Tek Chand Sharma (Estate Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 23/11/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 23/11/2023 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, D-Block Anand Vihar, Delhi-110092.
2. The Principal, Govt. Sarvodaya Kanya Vidyalaya at Krishna Nagar, Delhi 110051.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Govt. Sarvodaya Kanya Vidyalaya Krishna Nagar, Delhi-110051		
2	Building is comprised of	Ground plus two upper floors only		
3	Type of occupancy	Educational		
4	Type of case	New (Addition/Alteration) ✓ ✓		
5	Details of previous FSC	F.6/DFS/MS/School/2014/NDZ/1320 dated 21/10/14		
6	Fire safety directives letter no.	Delhi Fire Service Act.2007 And Rules 2010.		
7	Date of inspection	06/11/2023		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Tek Chand Sharma (Estate Manager)		
10	Year of construction	1954		
11	Applicant's letter no.	Emil dated 24/08/2023		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 mtrs.	6.0 mtrs. ✓	MR
	B Gate width	4.5 mtrs.	5.0 mtrs. ✓	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	03 nos.	04 nos. ✓	MR
	c Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 mtrs.	1.50 mtrs. each ✓	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	01 no.	01 no. ✓	MR
	E Width of corridor	1.50 mtrs.	2.0 mtrs. ✓	MR
	F Door size	1.0 mtrs.	1.0 mtrs. ✓	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	NA	NA	NA
	B Upper floor	NA	NA	NA


(u)

5.	Fire Extinguisher:				
	A	Total numbers	20 Nos.	20 Nos. ✓	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC ✓	MR
	C	ISI marking	ISI Marked	Provided ✓	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	02 Nos.	02 Nos. ✓	MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs. ✓	MR
	C	Nozzle diameter	05 mm	05 mm ✓	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	NA	NA
8	MOEFA:		NA	NA	NA
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 lpm	450 lpm ✓	MR
	B	Head of the pump	40 mtr	40 mtr ✓	MR
	C	Power supply	Required	Provided ✓	MR
	D	Auto starting of pump	Required	Provided ✓	MR

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 ltr	10,000 ltr ✓	MR
15 Exit Signage:				
		Required	Provided ✓	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17 Standby Power Supply:				
		N/A	N/A	N/A
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20 Special Fire Protection systems for protection of special Risks, if any:				
		N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. The shortcomings issued vide letter no. F.6/DFS/MS/School/2023/NDZ/33 dated 21/03/2023 have been rectified now.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F.6/DFS/MS/School/2014/NDZ/1320 dated 21/10/14 is recommended to be renewed.



Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO (L.N)

~~Dy. CPO (NDZ)~~

Handwritten signature
 13/11/23

Handwritten signature
 C.F.O.

Handwritten signature
 13/11/2023

Handwritten signature
 Director

Handwritten signature
 14/11/23

Handwritten signature

F.T letter is put up for sign. please