

c/39

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F-6/DFS/MS/SZ/2023/ EH/347

Dated: 23/11/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Jamies Pizzeria Located at Shop No. R-01 Fifth Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110075, in a building comprised of 4 Basement + Ground + 05 Upper Floors was issued FSC vide letter No. F6/DFS/MS/2020/SZ/EH/174, dated 07/12/2020. (Issued to Mall F6/DFS/MS/SZ/2022/62 Dated 09/12/2022) The premises was re - inspected by the officer concerned of this department on 16/11/2023 in the presence of Sh. Surender (Manager) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly" Group D (5th Floor) and valid up to 31/03/2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/11/2023..... at New Delhi by.

(Ajay Garg)
Director
Delhi Fire Service

ok

22/11/23

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, New Delhi.
2. The Manager, M/s Jamies Pizzeria Located at Shop No. R-01 Fifth Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/T
INSPECTION REPORT

1. Name & address of the building: Jamies Pizzeria Located at Shop No. R-01
Fifth Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110075.
2. Type of Occupancy : Class-D (Assembly)(**At Fifth Floor in the Mall**)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2020/SZ/EH/174, dated 07/12/2020
(Issued to Mall F6/DFS/MS/SZ/2022/62, dated 09/12/2022)
5. Fire Safety directives Letter No. :F6/DFS/MS/BP/2016/326 Dated 16/12/2016(issued to mall)
6. Date of inspection : 16/11/2023
7. Name of the Inspecting Officer ; ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Surender (Manager)
9. Year of Construction : 2019
10. Applicant's letter No. : 2023110218054, dated-07/11/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	Provided	MR
	• Gate width	06 mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits(Common With Mall)			
	a. Number of staircases	3	03 Provided (by Mall)	MR
	• Upper floors	NA	12 Provided by Mall	NA
	• Basements			
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided by Mall	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	2m Provided	MR
	f. Door Size	2m & 1.5 M	Open to corridor	MR
3.	Compartmentation(Common With Mall)			
	• Fire check door	NA	Provided by Mall	NA
	• Sealing of electrical shafts	NA	Provided by Mall	NA
	• Fire Rating of shaft door	NA	Provided by Mall	NA
	• Water Curtain	NA	Provided by Mall	NA
	• Fire Dampers	NA	Provided by Mall	NA

218

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		12 a/c per hour	Provided by Mall	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	03 nos. each type ABC, CO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reel	Common with mall		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required	Provided by Mall	MR
		36 m	Provided by Mall	MR
		5 mm	Provided by Mall	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke/ Heat	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided by Mall	MR
10.	Automatic Sprinkler System (Common with mall)			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	Provided	NA
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants: (common with the mall)			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm	Provided by Mall	MR
		1	3 Provided by Mall	MR
		Required	Provided by Mall	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	Provided by Mall	NA
		NA	Provided by Mall	NA
13.	Pumping Arrangements: Common with Mall			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	2850 lpm	Provided	MR
		120 m	Provided	MR
		02	Provided	MR
		180 LPM 2 Nos+ Water Curtain Pump 2280 LPM	Provided	MR
		120 m	Provided	MR
		2850 lpm	Provided	MR
		120 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		900lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR


1/5

N/9

14. Captive water Storage for fire fighting: Common with Mall			
<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	400000 ltr	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	20, 000 litres	Provided	MR
15. Exit Signage	Required	Provided By Mall	MR
16. Provision of Lifts Common with Mall			
<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	Provided By Mall	NA
	NA	Provided By Mall	NA
	NA	Provided By Mall	NA
	NA	Provided By Mall	NA
	NA	Provided By Mall	NA
17. Standby power supply	Required	Provided By Mall	MR
18. Refuge Area			
<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
	NA	NA	NA
19. Fire control room (Common with Mall)			
<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	Provided By Mall	NA
	NA	Provided By Mall	NA
	NA	Provided By Mall	NA
	NA	Provided By Mall	NA
	NA	Provided By Mall	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/2020/SZ/EH/174, dated 07/12/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended


 Signature of the Inspecting Officer
 Name UdaiVir Singh
 Designation ADO/SW

D.O (S.W)
 Cfo (S2)
 20/11/23