



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/WZ/2023/ 570


Dated: 28 / 11 / 2023

FIRE SAFETY CERTIFICATE

Certified that the M/s. A.P.S. Enterprises, Located at C-29-30, Rajdhani Market, Raghubir Nagar, Tagore Garden Extn., New Delhi – 110027, in a building comprised of ground floor only, owned/occupied by M/s. A.P.S. Enterprises, was issued Fire Safety Certificate vide Letter No. F6/DFS/MS/2020/WZ/230 dated 29/06/2020. The premises was re-inspected by officer concerned of this department on 08/11/2023 in the presence of Sh. Ajit Pal Singh and found that the said building/Premises have deemed complied with the fire prevention & fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rule 2010 & the said premises is fit for occupancy class "Industrial" (Storage of rectified and absolute Alcohol) (Group – G) with effect from 28/11/2023 for a period of three year in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 condition printed overleaf.

Issued on 28/11/2023 at New Delhi by.


(Atul Garg)
Director

7c

24/11/2023

Copy to:

1. The Owner/occupier M/s. A.P.S. Enterprises, Located at C-29-30, Rajdhani Market, Raghubir Nagar, Tagore Garden Extn., New Delhi – 110027.
2. The Executive Engineer (Building), MCD, Shivaji Enclave, Rajouri Garden New Delhi-110027.
3. Assistant Commissioner, (M & TP) Govt. of NCT of Delhi, O/o Commissioner of Excise, L & N Block, Vikas Bhawan, New Delhi – 110002.

INSPECTION REPORT

1. Name & address of the building	A.P.S. Enterprises, Located at C-29-30, Rajdhani Market, Raghubir Nagar, Tagore Garden Extn., New Delhi – 110027.			
2. Type of Occupancy	Godown (Storage of rectified spirit and Absolute Alcohol) 02 rooms of 14 x 16 ft ² Approx)			
3. Type of Case	Renewal (Ground Floor)			
4. Details of previous NOC	F6/DFS/MS/2020/WZ/230 dated 29/06/2020			
5. Fire Safety directives letter No	Nil			
6. Date of inspection	08/11/2023			
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)			
8. Name and designation of officers from the building side	Sh. Ajit Pal Singh			
9. Year of Construction	2009 (As per prev. Insp. report dated 12/06/2020)			
10. Applicant's letter No.	Email dated 16/10/2023			
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NR	NR	NR
	g. Door Size	1.00 mtr	1.50mtr Provided	MR
3.	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	06	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	180 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs	Provided	MR
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

ADO/MN
11/2023

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no. F6/DFS/MS/WZ/2023/1585 dated 28/07/2023 & F6/DFS/MS/WZ/2023/20/09/2023, have been complied.

Keeping in view the deemed compliance of the minimum standards of fire Prevention & fire safety required under the rules, the NOC Vide letter no. F6/DFS/MS/2020/WZ/230 dated 29/06/2020 recommended.

ADO/MN
21/11/23

(Signature)
24/11/23

(Signature)
09/11/2023

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

(Signature)
13/11/2023

O/SI-west
13/11/23

CFO
(Signature)
14/11/2023
Director
(Signature)
14/11/23
(Signature)
ADO/MN

Sir, F. T is put up for your kind perusal
& Signature please.

(Signature)