

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/Club/NDZ/2023/571

Dated :- 29/11/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s The Fraternity Club, Freemasons Hall located at Janpath, Connaught Place, New Delhi is comprised of Ground floor only in MASONIC complex was earlier granted FSC by this department vide letter No.F6/DFS/MS/Club/NDZ/2020/475 dated 06/11/20. Now, the premises was re-inspected by the officer concerned of this department on 17/11/23 in the presence of Mr. Shashank (Manager) and that the said club is fit for occupancy class **Assembly Building Group D** with effect from..29/11/2023..for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued ..29/11/2023.....at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service
See

Copy to:-

1. The Chief Architect, NDMC, Palika kendra, New Delhi.
2. The Jt Commissioners of Police, Lic department. First floor, Defence Colony Police Station, New Delhi. (Online id no.2023110218039 dated 04/11/23).
3. The Manager, M/s The Fraternity Club, Freemason's Hall, Janpath, Connaught Place, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is only for club.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building M/s The Fraternity Club, Freemasons Hall, Janpath, New Delhi
2. Type of Occupancy Assembly building
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/Club/NDZ/2020/475 dated 06/11/20
5. Fire safety directives No.- N/A
6. Date of inspection:- 17/11/23
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side:- Sh. Shashank(Manager)
9. Year of construction:-
10. Applicant's letter No:- Online id no.2023110218039 dated 04/11/23.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	09 mtr. ✓	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 mtr. & 1.5 mtr.	Provided ✓	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	12 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR ✓
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR ✓
	3) Nozzle diameter	05 mm	05 mm	MR ✓
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A

N/14

	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR ✓
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	Provided	MR ✓
	2) Number of hydrants per floor	Required	Provided	MR ✓
	3) Hose box	Required	Provided	MR ✓
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A ✓
	2) Hose box	N/A	N/A	N/A ✓
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR ✓
	b) Head of pump	40 mtr.	40 mtr.	MR ✓
	c) Power supply	Required	Provided	MR ✓
	d) Auto starting of pump	Required	Provided	MR ✓
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 ltr.	20,000 ltr.	MR ✓
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A

90 ✓


N/15

	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided ✓	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety as required under the rules, if approved, we may renew the FSC issued vide letter No. F6/DFS/MS/Club/NDZ/2020/475 dated 06/11/20, under rule 35(6) of Delhi Fire Service Rules-2010. Accordingly, DFS is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer



Name :- Ravinder Singh
Designation :- ADO (CC)

Do/CO- release

~~Dy. Insp. (M)~~
C.F.O.

Dir
22/11/23

24/11/2023