



No.F6/DFS/MS/School/SZ/2023/ 851

Dated: 04/12/2023

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Modern Public School located at GD-6, Pul Pehlad Pur, New Delhi-44, comprised of Basement (vacant) + Ground floor only was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2017/SZ/1072 dated 26.04.2017. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 30.11.2023 in the presence of Mr. Shushil Kumar (Manager) and found that now school building is comprised of Basement (vacant) + Ground + 01 upper floor and has deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Directorate of Education and the building (Basement (vacant) + Ground + 01 upper floor) is fit for occupancy of Group B "Educational Building" with effect from ..04/12/2023.. renewed for a period of three years, subject to conditions printed below.

Issued on... 04/12/2023 ...at New Delhi by

  
(Anul Garg)  
Director  
Delhi Fire Service  
DL  
30/11/23

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, M/s Modern Public School located at GD-6, Pul Pehlad Pur, New Delhi-44.

**Conditions for the validity of Fire Safety Certificate**

1. This Fire Safety Certificate is valid for Ground + 01 upper floor only.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used as per NBC/UBBL.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.

## INSPECTION REPORT

1	Name & address of the building	M/s Modern Public School located at GD-6, Pehladi Pur, New Delhi-44.			
2	Building is comprised of	Basement (vacant) + Ground + 01 upper floors			
3	Type of occupancy	Education, Group-B			
4	Type of case	Renewal- Addition/ Alteration (addition of 1 <sup>st</sup> floor of existing building)			
5	Details of previous FSC	F.6/DFS/MS/School/2017/SZ/1072 dated 26.04.2017 for Basement (vacant) & Ground floor only			
6	Fire safety direction letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011			
7	Date of inspection	30.11.2023			
8	Name of the inspecting officers	Rajesh Kumar Shukla ADO (M. Road)			
9	Name of the designation of officer from the building side	Mr. Shushil Kumar (Manager)			
10	Year of construction	2008 & 2017			
11	Applicant's letter no.	Outdoor diary no. 5238 dated 21.08.2023			
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per circular dated 01.03.2011	Provided at site	Remarks MR/NMI	
1	<b>Access to Building:</b>				
	A	Road width	Accessibility	Accessible	MR
	B	Gate width	NA	NA	NA
	C	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits:</b>				
	A	Number of staircases			
	a	Upper floor	02 nos.	02 nos.	MR
	b	Basement	02 nos.	02 nos.	MR
	B	Width of staircases			
	a	Upper floor	1 staircase of 1.5 mtrs or if main staircase width is < 1.5 mtrs an additional staircase of 0.75 mtrs width is required	1.48 mtrs & 1.26 mtrs	MR
	b	Basement	1.15 mtrs & 1.13 mtrs	1.15 mtrs & 1.13 mtrs	MR (Old Case)
	C	Protection of exits			
	a	Fire check door	NA	NA	NA
	b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	E	Width of corridor	NA	NA	NA
	F	Door size	1.0 mtrs.	Provided	MR
3	<b>Compartmentation:</b>				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft door	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>				
	A	Basement	Natural/Mechanical	Exhaust fan	MR
	B	Upper floor	NA	NA	NA

<b>5.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	06 nos.	06 nos.	MR
	<b>B</b>	Types	CO <sub>2</sub> & ABC	Provided	MR
	<b>C</b>	ISI marking	Required	Provided	MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>				
	<b>A</b>	Total numbers of each floor	NA	NA	NA
	<b>B</b>	Length of hose reel hose	NA	NA	NA
	<b>C</b>	Nozzle diameter	NA	NA	NA
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>				
	<b>A</b>	Type of detectors	NA	NA	NA
	<b>B</b>	Location of main panel	NA	NA	NA
	<b>C</b>	Location of repeater panel	NA	NA	NA
	<b>D</b>	Alternate source of power	NA	NA	NA
	<b>E</b>	Hooters	NA	NA	NA
<b>8</b>	<b>MOEFA:</b>				
			NA	NA	NA
<b>9</b>	<b>Public Address System:</b>				
			NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	Less than 200 m <sup>2</sup>	NA	NA
	<b>B</b>	Upper floor	NA	NA	NA
	<b>C</b>	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	Size of riser/down-comer	NA	NA	NA
	<b>B</b>	Number of hydrants per floor	NA	NA	NA
	<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	NA	NA	NA
	<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>				
	<b>A</b>	<b>Ground level</b>			
	<b>a</b>	Discharge of main pump	NA	NA	NA
	<b>b</b>	Head of main pump	NA	NA	NA
	<b>c</b>	Number of main pumps	NA	NA	NA
	<b>d</b>	Jockey pump out put	NA	NA	NA
	<b>e</b>	Jockey pump head	NA	NA	NA
	<b>f</b>	Standby pump out put	NA	NA	NA
	<b>g</b>	Standby pump head	NA	NA	NA
	<b>h</b>	Auto starting /manual stopping	NA	NA	NA
	<b>i</b>	Pump house access	NA	NA	NA
	<b>B</b>	<b>Terrace Level</b>			
	<b>a</b>	Discharge of pump	NA	NA	NA
	<b>b</b>	Head of the pump	NA	NA	NA
	<b>c</b>	Power supply	NA	NA	NA
	<b>d</b>	Auto starting of pump	NA	NA	NA

2/25

<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	NA	NA	NA
<b>15</b>	<b>Exit Signage:</b>	Required	Provided	MR
<b>16</b>	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply:</b>	NA	NA	NA
<b>18</b>	<b>Refuge Area:</b>			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
<b>19</b>	<b>Fire Control Room:</b>			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	NA		NA

**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

**Note :-**In the previous inspection report the building is comprised of Basement (vacant) & Ground floor only while during inspection dated 30.11.2023 school building was found now comprised of Basement (vacant) + Ground + 01 upper floors. Thus this is a case of addition/alteration hence inspection has been conducted as per Directorate of Education circular dated 01.03.2011.

The fire safety provisions provided in the building were randomly tested, checked and found functional at the time of inspection.

The shortcoming issued to the building by this department vide letter no. F6/DFS/MS/School/SZ/2023/177 dated 11.04.2023 has been rectified.

If agreed to the note above & in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular no. 3298 to 3398 dated 01.03.2011, the FSC issued vide letter no. F6/DFS/MS/School/2017/SZ/1072 dated 26.04.2017 is recommended to be renewed.

Accordingly, FSC is put up for approval and signatures please

*Rajesh Kumar Shukla*  
20/11/23

Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (M. Road)

DO (SD)  
*mull*  
20/11/23