

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2023/SZ/850

Dated: 01/12/2023

FIRE SAFETY CERTIFICATE

Certified that the **Ravindra Memorial Public School, Mandi Road, Sultanpur, New Delhi 110030** Comprised of Ground plus One upper floor owned/occupied by Ravindra Memorial Public School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2020/SZ/31 Dated 29/01/2020. The said premises was re-inspected by officer concerned of this department on 23/11/2023 in presence of Mr. Virender Singh and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Group - B Educational Building**" with effect from 01/12/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 01/12/2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Manager, Ravindra Memorial Public School, Mandi Road, Sultanpur, New Delhi 110030
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

N/12

INSPECTION REPORT

1	Name & Address of the Building	Ravindra Memorial Public School, Mandi Road, Sultanpur, New Delhi 110030		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus One upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2020/SZ/31 Dt. 29/01/2020		
6	Fire Safety Directives Letter No	DOE Circular date 17/01/2005		
7	Date of Inspection	23/11/2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Virender Singh		
10	Year of construction	2000		
11	Applicant letter No.	164/RNPS/251023 dated 26/10/2023		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	5 mtr	MR
	• Gate width	-NA-	NA	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	01 No	01 No	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr	1.50 mtr	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	12 ACPH	Open corridor	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	06 Nos	MR
	• Types	ABC	ABC & Co2 Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01 no each	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N/14

	<ul style="list-style-type: none"> Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2020/SZ/31 Dt. 29/01/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

1/14
28/11/23

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

1/14
28/11/23

CFO
28/11/2023

Director

1/14
29/11/23

ADP/MLP

As approved, F.T. letter is forup for your signature
Please.

1/14
30/11/23

Director

1/14
1/12/23