



75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2023/ 353

Dated: 05/12/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s. KFC Restaurant (A unit of sapphire Foods India Ltd.) Located at Shop No. 13, Kirti Nagar, Metro Station, New Delhi- 110015, running at Ground Floor only in a building comprised of Ground Floor only, was issued FSC vide this department letter no. F6/DFS/MS/EH/2020/146 dated 29/10/2020, the building/premises was re-inspected by the officer concerned of this department on 28/11/2023 in the presence of Sh. Jaspal (Assistant Manager) and found that the said premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" (Group - D) (Eating House) and **validity upto 31/03/2026** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, Conditions Printed Overleaf.

Issued on 05-12-2023 at New Delhi by.


(Atul Garg)
Director

Copy to: -

1. The owner/occupier, M/s. KFC restaurant (A unit of sapphire Foods India Ltd.) located at Shop No. 13, Kirti Nagar metro Station, New Delhi- 110015,. **Online Application ID no. 2023110618220 dated 06/11/2023**
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (adlcp.lic-dl@nic.in.)
3. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi-110027. (dhowestzone@gmail.com)

INSPECTION REPORT P/4

1. Name & address of the building	M/s. KFC restaurant (A unit of Sapphire Foods India Ltd.) Located at Shop No. 13, Kirti Nagar Metro Station, New Delhi- 110015.
2. Type of Occupancy	Assembly/ Restaurant
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/EH/2020/146 dated 29/10/2020
5. Fire Safety directives letter No	NBC (Part-IV)
6. Date of inspection	28/11/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Jaspal (Assistant Manager)
9. Year of Construction	2017 (As per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2023110618220 dated 06/11/2023

*** The Said Restaurant is running at ground floor in a P.D area of DMRC Metro Station, Kirti Nagar, New Delhi – 110015, in a building comprised of Ground floor only.**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	NA	On Main Road	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2m x 1, 1.50m x 1,	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	02 Nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

N/05

6	First-Aid Hose Reels.	Common with Metro Station		
	• Total numbers on each floor	01	Common with metro station	MR
	• Length of hose reel hose	30m	Common with metro station	MR
	• Nozzle diameter	5mm	Common with metro station	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants	Common with Metro Station		
	• Size of riser/down-comer	150 mm	Common with the Metro Station	MR
	• Number of hydrants per floor	Required	Common with the Metro Station	MR
	• Hose Box	Required	Common with the Metro Station	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.	Common with Metro Station		
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450lpm	Common with the Metro Station	MR
	➤ Head of the pump	40 m	Common with the Metro Station	MR
	➤ Power Supply	Required	Common with the Metro Station	MR
	➤ Auto Starting of pump	Required	Common with the Metro Station	MR
14	Captive Water Storage for fire fighting.	Common with Metro Station		
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	20, 000 ltrs	Common with the Metro Station	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts. n/ob			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire fighting arrangements provided in the building/restaurant were checked & found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/EH/2020/146 dated 29/10/2020 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

5/ADO/MN
9/11/2023

~~Dy CPO (W12)~~

~~Signature~~
04/12/2023

~~Signature~~
11/12/2023
Signature
11/12/23

~~Signature~~
29/11/2023

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

79
4/12/2023