



No. F6/DFS/MS/School/WZ/2023/ 868

Dated:- 06/12/2023

FIRE SAFETY CERTIFICATE

Certified that the **Rajbir Memorial Public School** Located at **Village Bakkarwala, P.O. Nangloi, Delhi-110041**, comprised of **Ground + 02 Upper Floors only** owned / occupied by **Rajbir Memorial Educational and Welfare Society**, was issued Fire Safety Certificate by this department vide letter No. **F.6/DFS/MS/School/WZ/2020/468 Dated 04/11/2020**. The said premise was re-inspected by the officer concerned of this department on 18/11/2023 in the presence of **Sh. Jai Bhagwan Sherawat (Owner)** and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., GNCT of Delhi, Circular no.262-362 dated 17.01.2005 and that the premises/building is fit for occupancy class "**Educational Building**" **Group B** with effect from 06/12/2023 for a period of **three years**, subject to compliance of the conditions, printed below.

Issued on 06/12/2023 at New Delhi by.


(Ajul Garg)
Director

Tel.No-(011-23414000)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Rajbir Memorial Public School, Village Bakkarwala, P.O. Nangloi, Delhi-110041.

OC
02/12/23

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **Rajbir Memorial Public School, Located at Village Bakkarwala, P.O. Nangloi, Delhi-110041**
2. Type of Occupancy : Educational (G + 02 Upper Floors only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2020/468 Dated 04/11/2020
5. Fire Safety directives Letter No. : D.O.E Circular no.262-362 dated 17.01.2005
6. Date of inspection : 18/11/2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Jai Bhagwan Sherawat (Owner)
9. Year of Construction : 2010
10. Applicant's letter No. : RBM/29/2023 dated 21/10/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 262-362 Dated 17.01.2005/ as per FSC dated 04/11/2020	Provided at site	Remarks MR/NMR
1	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 06 m 4.5 m NA 	<ul style="list-style-type: none"> Provided Provided NA 	<ul style="list-style-type: none"> MR MR NA
2	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 02 NA 	<ul style="list-style-type: none"> Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 1.5 m NA 	<ul style="list-style-type: none"> 1.65 m x 1 & 1.30 m x 1 NA 	<ul style="list-style-type: none"> MR(Old Case) NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace			
	<ul style="list-style-type: none"> • No of continuous staircase to terrace 	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> NA
	e. Width Of Corridor			
	<ul style="list-style-type: none"> • Width Of Corridor 	<ul style="list-style-type: none"> 1.5 m 	<ul style="list-style-type: none"> Provided 	<ul style="list-style-type: none"> MR
	f. Door Size			
	<ul style="list-style-type: none"> • Door Size 	<ul style="list-style-type: none"> 1.0 m 	<ul style="list-style-type: none"> Provided 	<ul style="list-style-type: none"> MR
3	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	<ul style="list-style-type: none"> 08 nos. ABC & CO₂ ISI marked 	<ul style="list-style-type: none"> 12 nos. Provided Provided 	<ul style="list-style-type: none"> MR MR MR

6.	First – Aid Hose Reels		02	MR
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system		NA	NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	02	MR
	• Hose Box	01	02	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 262-362 dated 17.01.2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2020/468 Dated 04/11/2020 is recommended.

Accordingly DFA is put up for approval please.

Aman Kumar Lathar
23/11/23
Aman Kumar Lathar
ADO (JWP)

1023

OC PGT (WZ)

28/11/2023

cto *11/11/2023*

Director *24/11/23*

ADP/PT

Sir,

F.F. letter is put-up for your signature pl.

ADP/PT

22/12/23
Am (WJP)