



No.F6/DFS/MS/School/NDZ/2023/ 863

Dated: 05/12/2023

FIRE SAFETY CERTIFICATE

Certified that the Sharda Sen Rajkiya Sarvodaya Kanya Vidyalaya (old name Sarvodaya Kanya Vidyalaya) located at Block-20, Trilok Puri, Delhi-110091, comprised of A-Block Ground plus three upper floors (New Building) & B-Block Ground plus one upper floor (Old building) owned/occupied by Sharda Sen Rajkiya Sarvodaya Kanya Vidyalaya was issued Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2017/ NDZ/1551 dated 31/10/17. The School building was re-inspected by the officer concerned of this department on 21/11/2023 in presence of Mrs. Neeraj Khatri (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 05/12/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 05/12/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
o/c @

Copy to:-

1. The Dy. Director of Education, D-Block, Anand Vihar, Delhi-110092.
2. The Principal, Sharda Sen Rajkiya Sarvodaya Kanya Vidyalaya, Block-20, Trilok Puri, Delhi-110091.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

21/17

INSPECTION REPORT

1	Name & address of the building	Sharda Sen Rajkiya Sarvodaya Kanya Vidyalaya, Block-20, Trilok Puri, Delhi-110091.		
2	Building is comprised of	A-Block Ground + 03 upper floors (New Building) & B-Block Ground + 01 upper floor (Old Building)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2017/NDZ/1551 dated 31.10.2017 ✓		
6	Fire safety directives letter no.	NBC Part -IV		
7	Date of inspection	21.11.2023		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs. Neerja Khatri (Principal)		
10	Year of construction	1916 & 2011		
11	Applicant's letter no.	Outdoor Diary No. 8311 dated -06.11.2023		
S.N	Minimum standard of fire prevention and fire safety U/R 33	NBC Part -IV requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A	Road width	6.0 mtrs.	6.0 mtrs. ✓ MR
	B	Gate width	N/A	4.5 mtrs ✓ MR
	C	Width of internal road	N/A	N/A N/A
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
	a	Upper floor	03 nos. (A Block) 05 nos. (B block)	Provided MR
	b	Basement	N/A	N/A N/A
	B	Width of staircases		
	a	Upper floor	1.50 mtrs. (A Block) 1.50 mtrs. (B Block)	1.07 mtrs. each & 1.35 mtrs. (B block) ✓ MR (Old Case)
	b	Basement	N/A	N/A N/A
	C	Protection of exits		
	a	Fire check door	N/A	N/A N/A
	b	Pressurization	N/A	N/A N/A
	D	No. of continuous staircases to terrace	03 no.	Provided ✓ MR
	E	Width of corridor	1.50 mtrs.	1.7 mtrs. ✓ MR
	F	Door size	1.0 mtrs.	1.0 mtrs. ✓ MR
3	Compartmentation:			
	A	Fire check door	NA	NA NA
	B	Sealing of electrical shafts	N/A	N/A NA
	C	Fire rating of shaft door	N/A	N/A NA
	D	Water curtain	N/A	N/A NA
	E	Fire dampers	N/A	N/A NA
4	Smoke Management System:			
	A	Basement	N/A	N/A N/A
	B	Upper floor	N/A	N/A N/A

2

5.	Fire Extinguisher:				
	A	Total numbers	27 nos.	37 nos. ✓	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC ✓	MR
	C	ISI marking	ISI Marked	ISI Marked ✓	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	04 nos.	Provided ✓	MR
	B	Length of hose reel hose	30 mtrs.	Provided ✓	MR
	C	Nozzle diameter	05 mm	Provided ✓	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	2 nos.450 LPM ✓	MR
	B	Head of the pump	40 mtrs.	40 mtrs. ✓	MR
	C	Power supply	Required	Provided ✓	MR
	D	Auto starting of pump	Auto	Provided ✓	MR

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	Required	Provided ✓	MR
E	Overhead tank capacity	10,000 ltrs	10,000 ltrs. ✓	MR
15	Exit Signage:			
		Required	Provided ✓	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Director of Education the FSC issued vide letter no. F6/DFS/MS/School/2017/NDZ/1551 dated 31.10.2017 is recommended to be renewed.



23/11/2023

Signature of the Inspecting Officer
Name- Yashwant Singh Meena
Designation- ADO (L.N)

DYCFO (NDZ)

King
25/11/23