



No. F6/DFS/MS/2023/School/ 859

Dated: 05/12/2023

FIRE SAFETY CERTIFICATE

Certified that the **Ambey Public School** located at **Gali No.59-60, B-Block, Sant Nagar, Burari, Delhi-110084** comprised of Ground & 03 upper floors but school is running at Ground + First floor only owned/ occupied by **Ambey Public School** was issued Fire Safety Certificated vide this office letter no.F6/DFS/MS/2020/School/WZ/500 dated 11.11.2020. The premise was inspected by the officer concerned of this department on 20.11.2023 in the presence of **Sh. Lal Bahadur Yadav (Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "**Group B Educational for ground & first floor only**" with effect from 05/12/2023... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 05/12/2023 at New Delhi


(Atul Garg)
Director
Ph:-011-23414000
gk

Copy to :-

1. The Director of Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Ambey Public School located at Gali No.59-60, B-Block, Sant Nagar, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. This fire safety certificate is valid ground & first floor for educational occupancy only and the use of second and third floor is not allowed in any case violation will be treated as cancellation of FSC.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

- 1 Name & address of the building : Ambey Public School at Gali No.59-60, B-block, Sant Nagar, Burari, Delhi-110084.
- 2 Type of Occupancy : Educational
- 3 Composition of building : Ground & 03 upper floors but School is running at Ground + first floor Only, 2nd & 3rd floor used for residence purpose of owner
- 4 Type of Case : Renewal
- 5 Details of previous NOC : F6/DFS/MS/2020/School/WZ/500 Dated: 11.11.2020
- 6 Fire Safety directives letter No : Nil
- 7 Date of inspection : 20.11.2023
- 8 Name of the Inspecting Officers : ADO (RN)
- 9 Name and designation of officers from the building side : Sh. Lal Bahadur Yadav (Principal)
10. Year of Construction : 2005
11. Applicant's letter No. : Online E-mail I.D Dated- 11.09.2020


	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular dated 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.40m & 95cm	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR


14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2020/School/WZ/500 dated: 11.11.2020.

Dy. Chief Fire Officer (WZ)


28/11/2023


21/11/2023
Signature of the Inspecting Officer
Name:- C.L. Meena
Designation:- Asst. Div. Officer (RN)