



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 857

Dated: 05/12/2023

FIRE SAFETY CERTIFICATE

Certified that the Jain Bharati Mrigavati Vidyalaya located at G.T. Karnal Road, Delhi-110036 comprised of Basement, Ground floor & 02 upper floors only owned/ occupied by the Jain Bharati Mrigavati Vidyalaya was issued FSC by this department vide letter F6/DFS/MS/2021/School/WZ/90 Dated 02.02.2021. The premise was inspected by the officer concerned of this department on 20.11.2023 in the presence of Mr. Yogesh Kumar (Senior Incharge) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rules 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class "Group B" Educational with effect from ...05/12/2023. for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 05/12/2023..... at New Delhi

(Atul Garg)
Director

Ph:-011-23414000

g-c-4p

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Jain Bharati Mrigavati Vidyalaya located at G.T. Karnal Road, Delhi-36.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

19
INSPECTION REPORT

1. Name & address of the building : Jain Bharati Mrigavati Vidyalaya at G.T. Kamal Road. Delhi-110036.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : Basement, Ground & 02 upper floors only
5. Details of previous NOC : F6/DFS/MS/2021/School/WZ/90 Dated: 02.02.2021
6. Fire Safety directives letter No : Nil
7. Date of inspection : 20.11.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Yogesh Kumar (Senior Incharge)
10. Year of Construction : 2007
11. Applicant's letter No. : Online E-mail dated: 04.11.2023

| | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Part-4 Requirements | Provided at site | Remarks MR/NMR |
|---|--|-------------------------|---------------------|----------------|
| 1 | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width | 06m | 06m | MR |
| | <ul style="list-style-type: none"> • Gate width | 4.5m | 04m | MR (old case) |
| | <ul style="list-style-type: none"> • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors | 03 | 03 | MR |
| | <ul style="list-style-type: none"> • Basements(Small basement) | 02 | 02 | MR |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors | 1.50m | 1.5m | MR |
| | <ul style="list-style-type: none"> • Basements | 1.50m | 1.30m & 1.50m | MR(old case) |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door | NA | NA | NA |
| | <ul style="list-style-type: none"> • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | Required | Provided | MR |
| | f. Door Size | 1m | 1m | MR |
| 3 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> • Fire check door | NA | NA | NA |
| | <ul style="list-style-type: none"> • Sealing of electrical shafts | NA | NA | NA |
| | <ul style="list-style-type: none"> • Fire Rating of shaft door | NA | NA | NA |
| | <ul style="list-style-type: none"> • Water Curtain | NA | NA | NA |
| | <ul style="list-style-type: none"> • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> • Basements | Required | Exhaust Fan | MR |
| | <ul style="list-style-type: none"> • Upper floors | Required | Natural Ventilation | MR |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers | 25nos | 30nos | MR |
| | <ul style="list-style-type: none"> • Types | ABC/CO2 | ABC-66/Co2-05 | MR |
| | <ul style="list-style-type: none"> • ISI marking | ISI Marked | Yes | MR |
| 6 | First-Aid Hose Reels. | | | |


| | | 03 | 03 | |
|----|---|------------|-------------|-----|
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 30m | 30m | MR |
| | | 5mm | 5mm | |
| 7 | Automatic fire detection and alarming system. | NA | NA | NA |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling | Required | Provided | MR |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | 100mm | 100mm | MR |
| | | 01 | 01 | MR |
| | | 01 | 01 | MR |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA | 02 | NA |
| | | NA | 02 | NA |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | 180lpm | 180lpm | MR |
| | | 40m | 40m | MR |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | 450lpm | 450lpm x 02 | MR |
| | | 40m | 40m | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | 10,000ltrs | 10,000ltrs | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby | N/A | N/A | N/A |
| | | N/A | N/A | N/A |

N/16

| | | | | |
|----|---|-----|-----|-----|
| | <ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A | N/A |


The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, it is recommended for renewal of Fire Safety Certificate issued vide letter of even no. F6/DFS/MS/2021/School/WZ/90 dated 02.02.2021 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


 Signature of the Inspecting Officer
 Name:- C.L. Meena
 Designation:- Asst. Div. Officer (RN)

Dy. Chief Fire Officer (WZ)


29/11


30/11/2023


11/12/23



362.....
29/11/2023