

C/74

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/SZ/2023/ 872

Dated: 11/11/2023

FIRE SAFETY CERTIFICATE

Certified that the Bal Bharti Public School Located at Sector - 12, Dwarka, New Delhi - 110078, comprised of Basement + Ground + 3UFs was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2020/SZ/455, dated 02/11/2020. The premises was re inspected by the officers concerned of this department on 28/11/2023 in the presence of Ms. Suruchi Gandhi (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance Delhi Fire Service Rules 2010 under Delhi Fire Service Act 2007 and that the premises is fit for occupancy class "Educational" Group B with effect from 11/12/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...11/12/2023... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

ec



Copy to:

1. Directorate of Education Old Secretariat Delhi - 110054.
2. The Principal, Bal Bharti Public School Located at Sector - 12, Dwarka, New Delhi - 110078.

Following fire safety directives must be adhered to:-

1. The pota cabins seen during the visit should not be use for school activities.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/26

INSPECTION REPORT

1. Name & address of the building: Bal Bharti Public School Located at Sector - 12, Dwarka, New Delhi - 110078.
2. Type of Occupancy : Educational (Basement +Ground+ 3 UFs)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2020/SZ/455, dated 02/11/2020
5. Fire Safety directives Letter No. : 3298-3398 dated 01/03/2011
6. Date of inspection : 28/11/2023
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side: Ms. Suruchi Gandhi (Principal)
9. Year of Construction : 2003
10. Applicant's letter No. : BBPS/DW/2023/1477 dated -16/11/2023

Total Area = 15794 sqm.
Covered Area = 8775 sqm
Class rooms = 65
No. of students = 2918

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/19, N/20 & N/21	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	5 mtr	4.5 m	MR(Being old case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	Provided	MR
	• Basements	05 Nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 m each	Varies from 1.37 to 1.5m	MR(Old case)
	• Basements	1.5 m each	Varies from 1.37 to 1.5m	MR(Old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.5m	Old case	MR
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c charge	Provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR

N/27


5.	Fire Extinguishers			
	• Total numbers	20 Nos.	Provided	MR
	• Types	ABC or CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	04 Nos.	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	04 Nos.	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	2x450 lpm	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltr	Provided	MR


Handwritten signature

N/28

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
				NA
17.	Standby power supply	NA	NA	
18.	Refuge Area			NA
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 & ABC, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter F6/DFS/MS/School/2020/SZ/455; dated 02/11/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 28/11/23
 Sign of Inspecting Officer
 Name: Vedpal
 Designation: DO/SW


 28/11/23
 Sign of Inspecting Officer
 Name: Udai vir Singh
 Designation: ADO/DWK

CFO (S2)
 29/11/2023
 PLS
 ADO/DWK
 Special.
 FIR